

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 12/30/2025 4:52:54 PM

JOB DESCRIPTION

RED-HILL
PFAS: Ka'amilo Wells P1

JOB NUMBER

380-189500-1

Eurofins Eaton Analytical Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
12/30/2025 4:52:54 PM



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	14
QC Association Summary	25
Lab Chronicle	26
Certification Summary	27
Method Summary	28
Sample Summary	29
Chain of Custody	30
Receipt Checklists	32

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-189500-1

Job ID: 380-189500-1

Eurofins Eaton Analytical Pomona

Job Narrative 380-189500-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 12/24/2025 10:37 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 0.7°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1

Lab Sample ID: 380-189500-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorobutanesulfonic acid (PFBS)	3.3		2.0	ng/L	1		533	Total/NA
Perfluoroheptanoic acid (PFHpA)	2.0		2.0	ng/L	1		533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.8		2.0	ng/L	1		533	Total/NA
Perfluorohexanoic acid (PFHxA)	4.2		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	5.0		2.0	ng/L	1		533	Total/NA
Perfluorooctanoic acid (PFOA)	4.2		2.0	ng/L	1		533	Total/NA
Perfluoropentanoic acid (PFPeA)	4.2		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	6.1		2.0	ng/L	1		537.1	Total/NA
Perfluorohexanoic acid (PFHxA)	3.7		2.0	ng/L	1		537.1	Total/NA
Perfluorooctanoic acid (PFOA)	4.7		2.0	ng/L	1		537.1	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	4.4		2.0	ng/L	1		537.1	Total/NA
Perfluorobutanesulfonic acid (PFBS)	3.8		2.0	ng/L	1		537.1	Total/NA
Perfluoroheptanoic acid (PFHpA)	2.4		2.0	ng/L	1		537.1	Total/NA

Client Sample ID: FB: Ka'amilo Wells P1

Lab Sample ID: 380-189500-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1

Lab Sample ID: 380-189500-1

Date Collected: 12/22/25 10:21

Matrix: Water

Date Received: 12/24/25 10:37

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluorobutanesulfonic acid (PFBS)	3.3		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluoroheptanoic acid (PFHpA)	2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluorohexanesulfonic acid (PFHxS)	3.8		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluorohexanoic acid (PFHxA)	4.2		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluorooctanesulfonic acid (PFOS)	5.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluorooctanoic acid (PFOA)	4.2		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluoropentanoic acid (PFPeA)	4.2		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 21:52	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	77		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C6 PFDA	92		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C5 PFHxA	83		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C4 PFHpA	90		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C8 PFOA	91		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C9 PFNA	95		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C7 PFUnA	99		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C2 PFDoA	99		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C4 PFBA	96		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C5 PFPeA	99		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C3 PFBS	105		50 - 200	12/28/25 14:25	12/29/25 21:52	1

Eurofins Eaton Analytical Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1

Lab Sample ID: 380-189500-1

Date Collected: 12/22/25 10:21

Matrix: Water

Date Received: 12/24/25 10:37

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 PFHxS	104		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C8 PFOS	106		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C2-4:2-FTS	117		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C2-6:2-FTS	109		50 - 200	12/28/25 14:25	12/29/25 21:52	1
13C2-8:2-FTS	105		50 - 200	12/28/25 14:25	12/29/25 21:52	1

Method: EPA 537.1 - Perfluorinated Alkyl Acids (LC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluorooctanesulfonic acid (PFOS)	6.1		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
N-methylperfluorooctanesulfonamide cetic acid (NMeFOSAA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
N-ethylperfluorooctanesulfonamide acetic acid (NEtFOSAA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluorohexanoic acid (PFHxA)	3.7		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluorooctanoic acid (PFOA)	4.7		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluorohexanesulfonic acid (PFHxS)	4.4		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluorobutanesulfonic acid (PFBS)	3.8		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluoroheptanoic acid (PFHpA)	2.4		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
Perfluorotridecanoic acid (PFTDA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:23	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	103		70 - 130	12/29/25 06:00	12/30/25 09:23	1
13C2 PFHxA	110		70 - 130	12/29/25 06:00	12/30/25 09:23	1
13C2 PFDA	105		70 - 130	12/29/25 06:00	12/30/25 09:23	1
13C3-GenX	101		70 - 130	12/29/25 06:00	12/30/25 09:23	1

Client Sample ID: FB: Ka'amilo Wells P1

Lab Sample ID: 380-189500-2

Date Collected: 12/22/25 10:21

Matrix: Water

Date Received: 12/24/25 10:37

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1

Eurofins Eaton Analytical Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Client Sample ID: FB: Ka'amilo Wells P1

Lab Sample ID: 380-189500-2

Date Collected: 12/22/25 10:21

Matrix: Water

Date Received: 12/24/25 10:37

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		12/28/25 14:25	12/29/25 22:01	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	90		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C6 PFDA	101		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C5 PFHxA	104		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C4 PFHpA	104		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C8 PFOA	100		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C9 PFNA	102		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C7 PFUnA	100		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C2 PFDoA	104		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C4 PFBA	108		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C5 PFPeA	106		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C3 PFBS	106		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C3 PFHxS	107		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C8 PFOS	107		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C2-4:2-FTS	113		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C2-6:2-FTS	106		50 - 200	12/28/25 14:25	12/29/25 22:01	1
13C2-8:2-FTS	110		50 - 200	12/28/25 14:25	12/29/25 22:01	1

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Client Sample ID: FB: Ka'amilo Wells P1

Lab Sample ID: 380-189500-2

Date Collected: 12/22/25 10:21

Matrix: Water

Date Received: 12/24/25 10:37

Method: EPA 537.1 - Perfluorinated Alkyl Acids (LC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
N-methylperfluorooctanesulfonamide cetic acid (NMeFOSAA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
N-ethylperfluorooctanesulfonamide acetic acid (NEtFOSAA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		12/29/25 06:00	12/30/25 09:33	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	102		70 - 130	12/29/25 06:00	12/30/25 09:33	1
13C2 PFHxA	102		70 - 130	12/29/25 06:00	12/30/25 09:33	1
13C2 PFDA	102		70 - 130	12/29/25 06:00	12/30/25 09:33	1
13C3-GenX	96		70 - 130	12/29/25 06:00	12/30/25 09:33	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1

Lab Sample ID: 380-189500-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.8		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	5.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	4.2		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	537.1	Total/NA
Perfluorooctanesulfonic acid (PFOS)	6.1		ng/L	4	2.0	537.1	Total/NA
Perfluorooctanoic acid (PFOA)	4.7		ng/L	4	2.0	537.1	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	4.4		ng/L	10	2.0	537.1	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	537.1	Total/NA

Client Sample ID: FB: Ka'amilo Wells P1

Lab Sample ID: 380-189500-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	537.1	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	537.1	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	537.1	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	537.1	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	537.1	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	d5NEFOS	PFHxA	PFDA	GenX
		(70-130)	(70-130)	(70-130)	(70-130)
380-189500-1	Ka'amilo Wells P1	103	110	105	101
380-189500-2	FB: Ka'amilo Wells P1	102	102	102	96
380-189551-B-1-A MS	Matrix Spike	104	111	110	109
380-189551-C-1-A MSD	Matrix Spike Duplicate	104	111	108	106
LCS 380-194808/22-A	Lab Control Sample	93	102	108	95
MBL 380-194808/20-A	Method Blank	108	105	108	98
MRL 380-194808/21-A	Lab Control Sample	99	101	103	100

Surrogate Legend

d5NEFOS = d5-NEtFOSAA

PFHxA = 13C2 PFHxA

PFDA = 13C2 PFDA

GenX = 13C3-GenX

Isotope Dilution Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-189500-1
 SDG: PFAS: Ka'amilo Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-188906-B-1-A MS	Matrix Spike	99	105	104	103	103	102	101	108
380-188906-C-1-A MSD	Matrix Spike Duplicate	99	105	109	104	105	107	106	105
380-189500-1	Ka'amilo Wells P1	77	92	83	90	91	95	99	99
380-189500-2	FB: Ka'amilo Wells P1	90	101	104	104	100	102	100	104
LCS 380-194747/24-A	Lab Control Sample	96	105	102	107	105	105	100	106
MBL 380-194747/22-A	Method Blank	88	97	100	100	105	103	100	100
MRL 380-194747/23-A	Lab Control Sample	90	106	111	106	105	106	103	108

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-188906-B-1-A MS	Matrix Spike	108	111	105	104	104	123	108	107
380-188906-C-1-A MSD	Matrix Spike Duplicate	108	111	116	112	113	118	116	113
380-189500-1	Ka'amilo Wells P1	96	99	105	104	106	117	109	105
380-189500-2	FB: Ka'amilo Wells P1	108	106	106	107	107	113	106	110
LCS 380-194747/24-A	Lab Control Sample	109	106	107	110	108	112	115	105
MBL 380-194747/22-A	Method Blank	107	105	111	106	108	124	112	108
MRL 380-194747/23-A	Lab Control Sample	112	111	115	107	110	124	110	110

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDoA = 13C2 PFDoA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-194747/22-A
Matrix: Water
Analysis Batch: 194911

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 194747

Analyte	MBL	MBL	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.48		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.25		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		12/28/25 14:25	12/29/25 18:53	1

Isotope Dilution	MBL	MBL	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C3 HFPO-DA	88		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C6 PFDA	97		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C5 PFHxA	100		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C4 PFHpA	100		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C8 PFOA	105		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C9 PFNA	103		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C7 PFUnA	100		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C2 PFDoA	100		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C4 PFBA	107		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C5 PFPeA	105		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C3 PFBS	111		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C3 PFHxS	106		50 - 200	12/28/25 14:25	12/29/25 18:53	1

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-194747/22-A
Matrix: Water
Analysis Batch: 194911

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 194747

Isotope Dilution	MBL MBL		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
13C8 PFOS	108		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C2-4:2-FTS	124		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C2-6:2-FTS	112		50 - 200	12/28/25 14:25	12/29/25 18:53	1
13C2-8:2-FTS	108		50 - 200	12/28/25 14:25	12/29/25 18:53	1

Lab Sample ID: LCS 380-194747/24-A
Matrix: Water
Analysis Batch: 194911

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 194747

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	60.4	56.5		ng/L		94	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	60.4	57.0		ng/L		94	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	60.4	57.3		ng/L		95	70 - 130
Perfluorobutanesulfonic acid (PFBS)	60.4	58.7		ng/L		97	70 - 130
Perfluorodecanoic acid (PFDA)	60.4	58.3		ng/L		97	70 - 130
Perfluorododecanoic acid (PFDoA)	60.4	56.9		ng/L		94	70 - 130
Perfluoroheptanoic acid (PFHpA)	60.4	58.2		ng/L		96	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	60.4	55.3		ng/L		92	70 - 130
Perfluorohexanoic acid (PFHxA)	60.4	59.8		ng/L		99	70 - 130
Perfluorononanoic acid (PFNA)	60.4	58.1		ng/L		96	70 - 130
Perfluorooctanesulfonic acid (PFOS)	60.4	57.2		ng/L		95	70 - 130
Perfluorooctanoic acid (PFOA)	60.4	59.4		ng/L		98	70 - 130
Perfluoroundecanoic acid (PFUnA)	60.4	58.0		ng/L		96	70 - 130
Perfluorobutanoic acid (PFBA)	60.4	57.3		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	60.4	60.5		ng/L		100	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	60.4	58.6		ng/L		97	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	60.4	56.8		ng/L		94	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	60.4	56.2		ng/L		93	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	60.4	56.3		ng/L		93	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	60.4	61.9		ng/L		103	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	60.4	60.5		ng/L		100	70 - 130
Perfluoropentanoic acid (PFPeA)	60.4	59.9		ng/L		99	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	60.4	58.6		ng/L		97	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-194747/24-A

Matrix: Water

Analysis Batch: 194911

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 194747

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	60.4	54.0		ng/L		90	70 - 130
LCS LCS							
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	96		50 - 200				
13C6 PFDA	105		50 - 200				
13C5 PFHxA	102		50 - 200				
13C4 PFHpA	107		50 - 200				
13C8 PFOA	105		50 - 200				
13C9 PFNA	105		50 - 200				
13C7 PFUnA	100		50 - 200				
13C2 PFDoA	106		50 - 200				
13C4 PFBA	109		50 - 200				
13C5 PFPeA	106		50 - 200				
13C3 PFBS	107		50 - 200				
13C3 PFHxS	110		50 - 200				
13C8 PFOS	108		50 - 200				
13C2-4:2-FTS	112		50 - 200				
13C2-6:2-FTS	115		50 - 200				
13C2-8:2-FTS	105		50 - 200				

Lab Sample ID: MRL 380-194747/23-A

Matrix: Water

Analysis Batch: 194911

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 194747

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.80	J	ng/L		89	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	1.72	J	ng/L		86	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	1.91	J	ng/L		95	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	1.85	J	ng/L		92	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	1.78	J	ng/L		89	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	1.87	J	ng/L		93	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	1.92	J	ng/L		96	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	1.98	J	ng/L		98	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	1.95	J	ng/L		97	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	1.84	J	ng/L		92	50 - 150
Perfluorononanoic acid (PFNA)	2.01	1.99	J	ng/L		99	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	1.94	J	ng/L		97	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	1.96	J	ng/L		97	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	1.91	J	ng/L		95	50 - 150
Perfluorobutanoic acid (PFBA)	2.01	1.96	J	ng/L		98	50 - 150

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-194747/23-A

Matrix: Water

Analysis Batch: 194911

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 194747

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.01	2.04	J	ng/L		102	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.01	1.96	J	ng/L		98	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.01	2.19	J	ng/L		109	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.01	1.82	J	ng/L		91	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.01	1.72	J	ng/L		86	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.01	1.83	J	ng/L		91	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.01	1.93	J	ng/L		96	50 - 150
Perfluoropentanoic acid (PFPeA)	2.01	1.95	J	ng/L		97	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.01	1.88	J	ng/L		93	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.01	1.99	J	ng/L		99	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	90		50 - 200
13C6 PFDA	106		50 - 200
13C5 PFHxA	111		50 - 200
13C4 PFHpA	106		50 - 200
13C8 PFOA	105		50 - 200
13C9 PFNA	106		50 - 200
13C7 PFUnA	103		50 - 200
13C2 PFDoA	108		50 - 200
13C4 PFBA	112		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	115		50 - 200
13C3 PFHxS	107		50 - 200
13C8 PFOS	110		50 - 200
13C2-4:2-FTS	124		50 - 200
13C2-6:2-FTS	110		50 - 200
13C2-8:2-FTS	110		50 - 200

Lab Sample ID: 380-188906-B-1-A MS

Matrix: Water

Analysis Batch: 194911

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 194747

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		60.2	55.9		ng/L		93	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		60.2	57.7		ng/L		96	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		60.2	58.6		ng/L		97	70 - 130

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-188906-B-1-A MS

Client Sample ID: Matrix Spike

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 194911

Prep Batch: 194747

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
Hexafluoropropylene Oxide	<2.0		60.2	59.9		ng/L		99	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	<2.0		60.2	57.3		ng/L		95	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		60.2	58.4		ng/L		97	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		60.2	58.8		ng/L		98	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		60.2	58.0		ng/L		96	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		60.2	58.7		ng/L		98	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		60.2	57.1		ng/L		95	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		60.2	60.9		ng/L		101	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		60.2	57.8		ng/L		96	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		60.2	58.5		ng/L		97	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		60.2	62.7		ng/L		104	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		60.2	57.0		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		60.2	60.0		ng/L		100	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		60.2	60.9		ng/L		101	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		60.2	61.2		ng/L		102	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		60.2	53.8		ng/L		89	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		60.2	58.6		ng/L		97	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		60.2	58.7		ng/L		97	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		60.2	59.4		ng/L		99	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		60.2	57.5		ng/L		95	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		60.2	59.8		ng/L		99	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		60.2	59.3		ng/L		98	70 - 130

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	99		50 - 200
13C6 PFDA	105		50 - 200
13C5 PFHxA	104		50 - 200
13C4 PFHpA	103		50 - 200
13C8 PFOA	103		50 - 200
13C9 PFNA	102		50 - 200
13C7 PFUnA	101		50 - 200
13C2 PFDoA	108		50 - 200
13C4 PFBA	108		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	105		50 - 200
13C3 PFHxS	104		50 - 200
13C8 PFOS	104		50 - 200

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-188906-B-1-A MS
Matrix: Water
Analysis Batch: 194911

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 194747

<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>MS MS Qualifier</i>	<i>Limits</i>
13C2-4:2-FTS	123		50 - 200
13C2-6:2-FTS	108		50 - 200
13C2-8:2-FTS	107		50 - 200

Lab Sample ID: 380-188906-C-1-A MSD
Matrix: Water
Analysis Batch: 194911

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 194747

<i>Analyte</i>	<i>Sample Result</i>	<i>Sample Qualifier</i>	<i>Spike Added</i>	<i>MSD Result</i>	<i>MSD Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec Limits</i>	<i>RPD</i>	<i>RPD Limit</i>
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		60.2	55.2		ng/L		92	70 - 130	1	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		60.2	57.1		ng/L		95	70 - 130	1	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		60.2	57.7		ng/L		96	70 - 130	2	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		60.2	59.3		ng/L		99	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		60.2	56.7		ng/L		94	70 - 130	1	30
Perfluorodecanoic acid (PFDA)	<2.0		60.2	56.7		ng/L		94	70 - 130	3	30
Perfluorododecanoic acid (PFDoA)	<2.0		60.2	60.8		ng/L		101	70 - 130	3	30
Perfluoroheptanoic acid (PFHpA)	<2.0		60.2	59.5		ng/L		99	70 - 130	3	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		60.2	57.7		ng/L		96	70 - 130	2	30
Perfluorohexanoic acid (PFHxA)	<2.0		60.2	54.0		ng/L		90	70 - 130	6	30
Perfluorononanoic acid (PFNA)	<2.0		60.2	57.7		ng/L		96	70 - 130	6	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		60.2	57.4		ng/L		95	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	<2.0		60.2	59.4		ng/L		99	70 - 130	1	30
Perfluoroundecanoic acid (PFUnA)	<2.0		60.2	59.8		ng/L		99	70 - 130	5	30
Perfluorobutanoic acid (PFBA)	<2.0		60.2	60.7		ng/L		101	70 - 130	6	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		60.2	61.0		ng/L		101	70 - 130	2	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		60.2	62.6		ng/L		104	70 - 130	3	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		60.2	59.8		ng/L		99	70 - 130	2	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		60.2	52.7		ng/L		87	70 - 130	2	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		60.2	57.2		ng/L		95	70 - 130	2	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		60.2	59.4		ng/L		99	70 - 130	1	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		60.2	60.0		ng/L		100	70 - 130	1	30
Perfluoropentanoic acid (PFPeA)	<2.0		60.2	57.5		ng/L		95	70 - 130	0	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		60.2	58.5		ng/L		97	70 - 130	2	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		60.2	57.5		ng/L		95	70 - 130	3	30

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	99		50 - 200
13C6 PFDA	105		50 - 200
13C5 PFHxA	109		50 - 200
13C4 PFHpA	104		50 - 200
13C8 PFOA	105		50 - 200
13C9 PFNA	107		50 - 200
13C7 PFUnA	106		50 - 200
13C2 PFDoA	105		50 - 200
13C4 PFBA	108		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	116		50 - 200
13C3 PFHxS	112		50 - 200
13C8 PFOS	113		50 - 200
13C2-4:2-FTS	118		50 - 200
13C2-6:2-FTS	116		50 - 200
13C2-8:2-FTS	113		50 - 200

Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS)

Lab Sample ID: MBL 380-194808/20-A
Matrix: Water
Analysis Batch: 194978

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 194808

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
Perfluorotridecanoic acid (PFTTrDA)	<0.36		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		12/29/25 06:00	12/30/25 08:24	1

Surrogate	MBL MBL		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
d5-NEtFOSAA	108		70 - 130	12/29/25 06:00	12/30/25 08:24	1
13C2 PFHxA	105		70 - 130	12/29/25 06:00	12/30/25 08:24	1
13C2 PFDA	108		70 - 130	12/29/25 06:00	12/30/25 08:24	1

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS) (Continued)

Lab Sample ID: MBL 380-194808/20-A
Matrix: Water
Analysis Batch: 194978

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 194808

<i>Surrogate</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3-GenX	98	Qualifier	70 - 130	12/29/25 06:00	12/30/25 08:24	1

Lab Sample ID: LCS 380-194808/22-A
Matrix: Water
Analysis Batch: 194978

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 194808

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>
	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>			<i>Limits</i>	<i>Limits</i>
Hexafluoropropylene Oxide	50.2	47.1		ng/L		94	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	50.2	52.3		ng/L		104	70 - 130
Perfluoroundecanoic acid (PFUnA)	50.2	53.5		ng/L		107	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	50.2	48.8		ng/L		97	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	50.2	46.9		ng/L		93	70 - 130
Perfluorohexanoic acid (PFHxA)	50.2	50.4		ng/L		100	70 - 130
Perfluorododecanoic acid (PFDoA)	50.2	53.2		ng/L		106	70 - 130
Perfluorooctanoic acid (PFOA)	50.2	51.8		ng/L		103	70 - 130
Perfluorodecanoic acid (PFDA)	50.2	52.3		ng/L		104	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	50.2	51.9		ng/L		103	70 - 130
Perfluorobutanesulfonic acid (PFBS)	50.2	51.6		ng/L		103	70 - 130
Perfluoroheptanoic acid (PFHpA)	50.2	50.7		ng/L		101	70 - 130
Perfluorononanoic acid (PFNA)	50.2	53.4		ng/L		106	70 - 130
Perfluorotetradecanoic acid (PFTA)	50.2	46.3		ng/L		92	70 - 130
Perfluorotridecanoic acid (PFTrDA)	50.2	57.4		ng/L		114	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	50.2	51.8		ng/L		103	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	50.2	51.5		ng/L		103	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	50.2	47.9		ng/L		95	70 - 130

<i>Surrogate</i>	<i>LCS</i>	<i>LCS</i>	<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
d5-NEtFOSAA	93		70 - 130
13C2 PFHxA	102		70 - 130
13C2 PFDA	108		70 - 130
13C3-GenX	95		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method: 537.1 - Perfluorinated Alkyl Acids (LC/MS) (Continued)

Lab Sample ID: MRL 380-194808/21-A
Matrix: Water
Analysis Batch: 194978

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 194808

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.01	1.87	J	ng/L		93	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.01	2.14	J	ng/L		106	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.01	2.17	J	ng/L		108	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.01	2.12	J	ng/L		105	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.01	2.07	J	ng/L		103	50 - 150
Perfluorohexanoic acid (PFHxA)	2.01	2.03	J	ng/L		101	50 - 150
Perfluorododecanoic acid (PFDoA)	2.01	2.09	J	ng/L		104	50 - 150
Perfluorooctanoic acid (PFOA)	2.01	2.12	J	ng/L		105	50 - 150
Perfluorodecanoic acid (PFDA)	2.01	2.16	J	ng/L		107	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.01	2.04	J	ng/L		101	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.01	2.14	J	ng/L		106	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.01	2.14	J	ng/L		106	50 - 150
Perfluorononanoic acid (PFNA)	2.01	2.29	J	ng/L		114	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.01	1.79	J	ng/L		89	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.01	2.27	J	ng/L		113	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.01	2.03	J	ng/L		101	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.01	1.85	J	ng/L		92	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.01	2.10	J	ng/L		104	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	99		70 - 130
13C2 PFHxA	101		70 - 130
13C2 PFDA	103		70 - 130
13C3-GenX	100		70 - 130

Lab Sample ID: 380-189551-B-1-A MS
Matrix: Water
Analysis Batch: 194978

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 194808

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		50.2	50.5		ng/L		101	70 - 130
Perfluorooctanesulfonic acid (PFOS)	3.7		50.2	56.6		ng/L		105	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		50.2	50.8		ng/L		101	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		50.2	52.0		ng/L		104	70 - 130

Eurofins Eaton Analytical Pomona

QC Association Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-189500-1
 SDG: PFAS: Ka'amilo Wells P1

LCMS

Prep Batch: 194747

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189500-1	Ka'amilo Wells P1	Total/NA	Water	533	
380-189500-2	FB: Ka'amilo Wells P1	Total/NA	Water	533	
MBL 380-194747/22-A	Method Blank	Total/NA	Water	533	
LCS 380-194747/24-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-194747/23-A	Lab Control Sample	Total/NA	Water	533	
380-188906-B-1-A MS	Matrix Spike	Total/NA	Water	533	
380-188906-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Prep Batch: 194808

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189500-1	Ka'amilo Wells P1	Total/NA	Water	537.1 DW	
380-189500-2	FB: Ka'amilo Wells P1	Total/NA	Water	537.1 DW	
MBL 380-194808/20-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-194808/22-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-194808/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-189551-B-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-189551-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

Analysis Batch: 194911

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189500-1	Ka'amilo Wells P1	Total/NA	Water	533	194747
380-189500-2	FB: Ka'amilo Wells P1	Total/NA	Water	533	194747
MBL 380-194747/22-A	Method Blank	Total/NA	Water	533	194747
LCS 380-194747/24-A	Lab Control Sample	Total/NA	Water	533	194747
MRL 380-194747/23-A	Lab Control Sample	Total/NA	Water	533	194747
380-188906-B-1-A MS	Matrix Spike	Total/NA	Water	533	194747
380-188906-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	194747

Analysis Batch: 194978

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189500-1	Ka'amilo Wells P1	Total/NA	Water	537.1	194808
380-189500-2	FB: Ka'amilo Wells P1	Total/NA	Water	537.1	194808
MBL 380-194808/20-A	Method Blank	Total/NA	Water	537.1	194808
LCS 380-194808/22-A	Lab Control Sample	Total/NA	Water	537.1	194808
MRL 380-194808/21-A	Lab Control Sample	Total/NA	Water	537.1	194808
380-189551-B-1-A MS	Matrix Spike	Total/NA	Water	537.1	194808
380-189551-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1	194808

Lab Chronicle

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-189500-1
 SDG: PFAS: Ka'amilo Wells P1

Client Sample ID: Ka'amilo Wells P1

Lab Sample ID: 380-189500-1

Date Collected: 12/22/25 10:21

Matrix: Water

Date Received: 12/24/25 10:37

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			194747	E9PK	EA POM	12/28/25 14:25
Total/NA	Analysis	533		1	194911	M7ML	EA POM	12/29/25 21:52
Total/NA	Prep	537.1 DW			194808	G9MN	EA POM	12/29/25 06:00
Total/NA	Analysis	537.1		1	194978	SZ9R	EA POM	12/30/25 09:23

Client Sample ID: FB: Ka'amilo Wells P1

Lab Sample ID: 380-189500-2

Date Collected: 12/22/25 10:21

Matrix: Water

Date Received: 12/24/25 10:37

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			194747	E9PK	EA POM	12/28/25 14:25
Total/NA	Analysis	533		1	194911	M7ML	EA POM	12/29/25 22:01
Total/NA	Prep	537.1 DW			194808	G9MN	EA POM	12/29/25 06:00
Total/NA	Analysis	537.1		1	194978	SZ9R	EA POM	12/30/25 09:33

Laboratory References:

EA POM = Eurofins Eaton Analytical Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Laboratory: Eurofins Eaton Analytical Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
537.1	Perfluorinated Alkyl Acids (LC/MS)	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Eaton Analytical Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-189500-1
SDG: PFAS: Ka'amilo Wells P1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-189500-1	Ka'amilo Wells P1	Water	12/22/25 10:21	12/24/25 10:37	Hawaii
380-189500-2	FB: Ka'amilo Wells P1	Water	12/22/25 10:21	12/24/25 10:37	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Monrovia, CA (Suite 100)
 750 Royal Oaks Drive Suite 100
 Monrovia, CA 91016
 Phone (626) 386-1100

Chain of Custody Record



Client Information		Lab P#:		Carrier Tracking No(s):		COC No:	
750 Royal Oaks Drive Suite 100 Monrovia, CA 91016 Phone (626) 386-1100		Arada, Rachelle		380-27941-2757.2		380-27941-2757.2	
Client Contact: krk iwamoto Company: City & County of Honolulu		E-Mail: Rachelle.Arada@et.euronisus.com		State of Origin:		Page: Page 2 of 2	
Address: 630 South Beretama Street, Chemistry Lab Honolulu State, Zip: HI, 96843		PWSID:		Analysis Requested		Job #:	
Due Date Requested:		Field Filled Sample (Yes or No)		Form M/MSD (Yes or No)		Preservation Codes:	
TAT Requested (days): RUSH		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		M - Hexane N - None O - AsNaO2 P - Na2O4S Q - Na2SO3 R - Na2SO4 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 Y - Trizma Z - other (specify)	
Compliance Project: Δ No		Perform M/MSD (Yes or No)		R A Q DA Y I		A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other:	
PO #: C20525101 exp 05312023		Field Filtered Sample (Yes or No)		633 - All Analytes		Total Number of Containers	
WO #: 3800111		<input checked="" type="checkbox"/>		637.1_DW_PREG - 637.1 Full Lmt		Special Instructions/Note:	
Project #: 3800111		Sample Date		637.2_PREG - (MOD) 62plus PLUS TICs			
Site: RED-HILL/HBWS sites Event Desc: RUSH Weekly Red Hill		Sample Time		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Identification		Sample Type (C=Comp, G=grab)		80168_GRO_LL - (MOD) GRO			
Ka'amilo Wells P1		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
FB: Ka'amilo Wells P1		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Time		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Date		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Time		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Date		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Time		22-Dec-2025		637.2_PREG - (MOD) 62plus PLUS TICs			
Sample Date		22-Dec-2025		80168_DRO_LL_CS - HNL Ranges: C10-C24/C24-C38/CS-C18			
Sample Time		22-Dec-2025		80168_GRO_LL - (MOD) GRO			
Sample Date		22-Dec-2025		SUBCONTRACT - 625 PAH Physia LL (EAL) + TICs			
Sample Time		22-Dec-2025		637.1_DW_PREG - 637.1 Full Lmt			
Sample Date		2					

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-189500-1
SDG Number: PFAS: Ka'amilo Wells P1

Login Number: 189500

List Number: 1

Creator: Segura, Ryan

List Source: Eurofins Eaton Analytical Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

