

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 2/11/2026 5:58:58 PM

JOB DESCRIPTION

RED-HILL
PFAS: Aiea Gulch Wells Pump 2
RUSH Weekly Red Hill

JOB NUMBER

380-196035-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
2/11/2026 5:58:58 PM

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	15
QC Association Summary	26
Lab Chronicle	27
Certification Summary	28
Method Summary	29
Sample Summary	30
Chain of Custody	31
Receipt Checklists	32



Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-196035-1

Job ID: 380-196035-1

Eurofins Pomona

Job Narrative 380-196035-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 2/4/2026 9:22 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperatures of the 3 coolers at receipt time were 1.7°C, 2.1°C and 2.5°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-196035-1

☐ No Detections.

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-196035-2

☐ No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-196035-1

Date Collected: 02/02/26 11:39

Matrix: Drinking Water

Date Received: 02/04/26 09:22

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9CI-PF3ONS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:05	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	91		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C6 PFDA	98		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C5 PFHxA	102		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C4 PFHpA	98		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C8 PFOA	99		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C9 PFNA	97		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C7 PFUnA	98		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C2 PFDoA	98		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C4 PFBA	101		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C5 PFPeA	99		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C3 PFBS	110		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C3 PFHxS	113		50 - 200	02/09/26 06:54	02/09/26 20:05	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-196035-1

Date Collected: 02/02/26 11:39

Matrix: Drinking Water

Date Received: 02/04/26 09:22

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	108		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C2-4:2-FTS	112		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C2-6:2-FTS	107		50 - 200	02/09/26 06:54	02/09/26 20:05	1
13C2-8:2-FTS	102		50 - 200	02/09/26 06:54	02/09/26 20:05	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9CI-PF3ONS)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:23	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	111		70 - 130			02/06/26 15:29	02/09/26 10:23	1
13C2 PFHxA	119		70 - 130			02/06/26 15:29	02/09/26 10:23	1
13C2 PFDA	120		70 - 130			02/06/26 15:29	02/09/26 10:23	1
13C3-GenX	120		70 - 130			02/06/26 15:29	02/09/26 10:23	1

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-196035-2

Date Collected: 02/02/26 11:39

Matrix: Water

Date Received: 02/04/26 09:22

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)

Lab Sample ID: 380-196035-2

Date Collected: 02/02/26 11:39

Matrix: Water

Date Received: 02/04/26 09:22

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		02/09/26 06:54	02/09/26 20:15	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	95		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C6 PFDA	99		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C5 PFHxA	100		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C4 PFHpA	100		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C8 PFOA	100		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C9 PFNA	99		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C7 PFUnA	95		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C2 PFDoA	99		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C4 PFBA	100		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C5 PFPeA	101		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C3 PFBS	112		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C3 PFHxS	115		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C8 PFOS	111		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C2-4:2-FTS	118		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C2-6:2-FTS	105		50 - 200	02/09/26 06:54	02/09/26 20:15	1
13C2-8:2-FTS	101		50 - 200	02/09/26 06:54	02/09/26 20:15	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-196035-2

Date Collected: 02/02/26 11:39

Matrix: Water

Date Received: 02/04/26 09:22

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Perfluorotridecanoic acid (PFTTrDA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		02/06/26 15:29	02/09/26 10:32	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	108		70 - 130			02/06/26 15:29	02/09/26 10:32	1
13C2 PFHxA	115		70 - 130			02/06/26 15:29	02/09/26 10:32	1
13C2 PFDA	120		70 - 130			02/06/26 15:29	02/09/26 10:32	1
13C3-GenX	120		70 - 130			02/06/26 15:29	02/09/26 10:32	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)

Lab Sample ID: 380-196035-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)

Lab Sample ID: 380-196035-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	RL	Method	Prep Type
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-196035-1	AIEA GULCH WELLS PUMP 2 (331	111	119	120	120
Surrogate Legend					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-195691-B-1-A MS	Matrix Spike	112	123	119	121
380-195691-C-1-A MSD	Matrix Spike Duplicate	107	119	119	123
380-196035-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	108	115	120	120
LCS 380-204090/21-A	Lab Control Sample	101	108	120	106
MBL 380-204090/19-A	Method Blank	106	110	128	104
MRL 380-204090/20-A	Lab Control Sample	97	106	119	100
Surrogate Legend					
d5NEFOS = d5-NEtFOSAA					
PFHxA = 13C2 PFHxA					
PFDA = 13C2 PFDA					
GenX = 13C3-GenX					

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-196035-1	AIEA GULCH WELLS PUMP 2 (331	91	98	102	98	99	97	98	98

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-196035-1	AIEA GULCH WELLS PUMP 2 (331	101	99	110	113	108	112	107	102

Surrogate Legend

HFPODA = 13C3 HFPO-DA
C6PFDA = 13C6 PFDA
13C5PHA = 13C5 PFHxA
C4PFHA = 13C4 PFHpA
C8PFOA = 13C8 PFOA
C9PFNA = 13C9 PFNA
13C7PUA = 13C7 PFUnA
PFDaA = 13C2 PFDaA
PFBA = 13C4 PFBA
PFPeA = 13C5 PFPeA
C3PFBS = 13C3 PFBS
C3PFHS = 13C3 PFHxS
C8PFOS = 13C8 PFOS
42FTS = 13C2-4:2-FTS
62FTS = 13C2-6:2-FTS
82FTS = 13C2-8:2-FTS

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-196010-E-1-A MS	Matrix Spike	109	110	108	109	109	111	108	110
380-196010-F-1-A MSD	Matrix Spike Duplicate	107	106	110	109	107	108	107	103
380-196035-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	95	99	100	100	100	99	95	99
LCS 380-204366/22-A	Lab Control Sample	101	104	105	107	106	111	106	107
MBL 380-204366/20-A	Method Blank	94	104	103	102	99	103	102	103
MRL 380-204366/21-A	Lab Control Sample	97	99	102	101	103	101	99	99

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-196010-E-1-A MS	Matrix Spike	106	114	109	113	109	111	105	104
380-196010-F-1-A MSD	Matrix Spike Duplicate	106	107	107	113	107	110	104	107
380-196035-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	100	101	112	115	111	118	105	101
LCS 380-204366/22-A	Lab Control Sample	105	111	108	117	112	110	108	110
MBL 380-204366/20-A	Method Blank	104	114	116	118	110	116	113	110
MRL 380-204366/21-A	Lab Control Sample	102	107	113	118	111	117	113	111

Surrogate Legend

HFPODA = 13C3 HFPO-DA
C6PFDA = 13C6 PFDA

Eurofins Pomona

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFD_oA = 13C2 PFD_oA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-204366/20-A

Matrix: Water

Analysis Batch: 204503

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 204366

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	<0.30		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9CI-PF3ONS)	<0.30		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	0.540	J	2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<0.25		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		02/09/26 06:54	02/09/26 17:17	1
Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits			Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	94		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C6 PFDA	104		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C5 PFHxA	103		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C4 PFHpA	102		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C8 PFOA	99		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C9 PFNA	103		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C7 PFUnA	102		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C2 PFDoA	103		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C4 PFBA	104		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C5 PFPeA	114		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C3 PFBS	116		50 - 200			02/09/26 06:54	02/09/26 17:17	1
13C3 PFHxS	118		50 - 200			02/09/26 06:54	02/09/26 17:17	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-204366/20-A

Matrix: Water

Analysis Batch: 204503

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 204366

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	110		50 - 200	02/09/26 06:54	02/09/26 17:17	1
13C2-4:2-FTS	116		50 - 200	02/09/26 06:54	02/09/26 17:17	1
13C2-6:2-FTS	113		50 - 200	02/09/26 06:54	02/09/26 17:17	1
13C2-8:2-FTS	110		50 - 200	02/09/26 06:54	02/09/26 17:17	1

Lab Sample ID: LCS 380-204366/22-A

Matrix: Water

Analysis Batch: 204503

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 204366

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	120	111		ng/L		92	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	120	111		ng/L		92	70 - 130
4,8-Dioxo-3H-perfluorononanoic acid (ADONA)	120	112		ng/L		93	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	120	116		ng/L		96	70 - 130
Perfluorobutanesulfonic acid (PFBS)	120	111		ng/L		92	70 - 130
Perfluorodecanoic acid (PFDA)	120	115		ng/L		95	70 - 130
Perfluorododecanoic acid (PFDoA)	120	110		ng/L		92	70 - 130
Perfluoroheptanoic acid (PFHpA)	120	111		ng/L		92	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	120	106		ng/L		88	70 - 130
Perfluorohexanoic acid (PFHxA)	120	110		ng/L		91	70 - 130
Perfluorononanoic acid (PFNA)	120	108		ng/L		89	70 - 130
Perfluorooctanesulfonic acid (PFOS)	120	110		ng/L		92	70 - 130
Perfluorooctanoic acid (PFOA)	120	110		ng/L		91	70 - 130
Perfluoroundecanoic acid (PFUnA)	120	112		ng/L		93	70 - 130
Perfluorobutanoic acid (PFBA)	120	114		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	120	106		ng/L		88	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	120	114		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	120	114		ng/L		95	70 - 130
Nonfluoro-3,6-dioxahexanoic acid (NFDHA)	120	116		ng/L		96	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	120	116		ng/L		96	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	120	117		ng/L		97	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	120	114		ng/L		95	70 - 130
Perfluoropentanoic acid (PFPeA)	120	115		ng/L		96	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	120	110		ng/L		91	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-204366/22-A

Matrix: Water

Analysis Batch: 204503

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 204366

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	120	107		ng/L		88	70 - 130
	LCS	LCS					
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	101		50 - 200				
13C6 PFDA	104		50 - 200				
13C5 PFHxA	105		50 - 200				
13C4 PFHpA	107		50 - 200				
13C8 PFOA	106		50 - 200				
13C9 PFNA	111		50 - 200				
13C7 PFUnA	106		50 - 200				
13C2 PFDoA	107		50 - 200				
13C4 PFBA	105		50 - 200				
13C5 PFPeA	111		50 - 200				
13C3 PFBS	108		50 - 200				
13C3 PFHxS	117		50 - 200				
13C8 PFOS	112		50 - 200				
13C2-4:2-FTS	110		50 - 200				
13C2-6:2-FTS	108		50 - 200				
13C2-8:2-FTS	110		50 - 200				

Lab Sample ID: MRL 380-204366/21-A

Matrix: Water

Analysis Batch: 204503

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 204366

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	2.13	J	ng/L		106	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	2.17	J	ng/L		108	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	2.11	J	ng/L		105	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	2.25	J	ng/L		112	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	2.24	J	ng/L		112	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.33	J	ng/L		116	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	2.09	J	ng/L		104	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	2.27	J	ng/L		113	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	2.06	J	ng/L		103	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	2.17	J	ng/L		108	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.23	J	ng/L		111	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	2.13	J	ng/L		107	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	2.22	J	ng/L		111	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.22	J	ng/L		111	50 - 150
Perfluorobutanoic acid (PFBA)	2.00	2.27	J	ng/L		113	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-204366/21-A

Matrix: Water

Analysis Batch: 204503

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 204366

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.00	2.20	J	ng/L		110	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.00	2.35	J	ng/L		117	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.00	2.55	J	ng/L		127	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.00	2.29	J	ng/L		114	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	2.00	2.14	J	ng/L		107	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.00	2.22	J	ng/L		111	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.00	2.17	J	ng/L		108	50 - 150
Perfluoropentanoic acid (PFPeA)	2.00	2.33	J	ng/L		116	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.00	2.20	J	ng/L		110	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.00	2.11	J	ng/L		105	50 - 150

Isotope Dilution	%Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	97		50 - 200
13C6 PFDA	99		50 - 200
13C5 PFHxA	102		50 - 200
13C4 PFHpA	101		50 - 200
13C8 PFOA	103		50 - 200
13C9 PFNA	101		50 - 200
13C7 PFUnA	99		50 - 200
13C2 PFDoA	99		50 - 200
13C4 PFBA	102		50 - 200
13C5 PFPeA	107		50 - 200
13C3 PFBS	113		50 - 200
13C3 PFHxS	118		50 - 200
13C8 PFOS	111		50 - 200
13C2-4:2-FTS	117		50 - 200
13C2-6:2-FTS	113		50 - 200
13C2-8:2-FTS	111		50 - 200

Lab Sample ID: 380-196010-E-1-A MS

Matrix: Water

Analysis Batch: 204503

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 204366

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		121	111		ng/L		92	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		121	111		ng/L		92	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		121	113		ng/L		93	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-196010-E-1-A MS

Matrix: Water

Analysis Batch: 204503

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 204366

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		121	112		ng/L		93	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	<2.0		121	114		ng/L		93	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		121	115		ng/L		95	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		121	114		ng/L		94	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		121	112		ng/L		92	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		121	114		ng/L		93	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		121	111		ng/L		91	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		121	112		ng/L		93	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		121	112		ng/L		91	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		121	113		ng/L		92	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		121	114		ng/L		94	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		121	114		ng/L		93	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		121	111		ng/L		92	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		121	109		ng/L		90	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		121	117		ng/L		97	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		121	119		ng/L		98	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		121	111		ng/L		92	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		121	110		ng/L		91	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		121	105		ng/L		87	70 - 130
Perfluoropentanoic acid (PFPeA)	2.1		121	115		ng/L		93	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		121	113		ng/L		93	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		121	106		ng/L		88	70 - 130

Isotope Dilution	MS %Recovery	MS Qualifier	Limits
13C3 HFPO-DA	109		50 - 200
13C6 PFDA	110		50 - 200
13C5 PFHxA	108		50 - 200
13C4 PFHpA	109		50 - 200
13C8 PFOA	109		50 - 200
13C9 PFNA	111		50 - 200
13C7 PFUnA	108		50 - 200
13C2 PFDoA	110		50 - 200
13C4 PFBA	106		50 - 200
13C5 PFPeA	114		50 - 200
13C3 PFBS	109		50 - 200
13C3 PFHxS	113		50 - 200
13C8 PFOS	109		50 - 200

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-196010-E-1-A MS

Matrix: Water

Analysis Batch: 204503

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 204366

Isotope Dilution	MS %Recovery	MS Qualifier	Limits
13C2-4:2-FTS	111		50 - 200
13C2-6:2-FTS	105		50 - 200
13C2-8:2-FTS	104		50 - 200

Lab Sample ID: 380-196010-F-1-A MSD

Matrix: Water

Analysis Batch: 204503

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 204366

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		121	112		ng/L		93	70 - 130	1	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<2.0		121	114		ng/L		95	70 - 130	3	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		121	112		ng/L		93	70 - 130	0	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		121	113		ng/L		93	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		121	116		ng/L		95	70 - 130	1	30
Perfluorodecanoic acid (PFDA)	<2.0		121	116		ng/L		96	70 - 130	0	30
Perfluorododecanoic acid (PFDoA)	<2.0		121	114		ng/L		94	70 - 130	0	30
Perfluorooheptanoic acid (PFHpA)	<2.0		121	112		ng/L		92	70 - 130	0	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		121	111		ng/L		91	70 - 130	3	30
Perfluorohexanoic acid (PFHxA)	<2.0		121	113		ng/L		92	70 - 130	2	30
Perfluorononanoic acid (PFNA)	<2.0		121	114		ng/L		95	70 - 130	2	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		121	113		ng/L		93	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	<2.0		121	114		ng/L		93	70 - 130	1	30
Perfluoroundecanoic acid (PFUnA)	<2.0		121	110		ng/L		91	70 - 130	4	30
Perfluorobutanoic acid (PFBA)	<2.0		121	120		ng/L		98	70 - 130	5	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		121	108		ng/L		90	70 - 130	3	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		121	112		ng/L		92	70 - 130	2	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		121	115		ng/L		95	70 - 130	2	30
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		121	112		ng/L		92	70 - 130	6	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	<2.0		121	109		ng/L		91	70 - 130	2	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		121	115		ng/L		96	70 - 130	5	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		121	113		ng/L		94	70 - 130	7	30
Perfluoropentanoic acid (PFPeA)	2.1		121	121		ng/L		99	70 - 130	5	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		121	113		ng/L		94	70 - 130	0	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		121	108		ng/L		90	70 - 130	2	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	107		50 - 200
13C6 PFDA	106		50 - 200
13C5 PFHxA	110		50 - 200
13C4 PFHpA	109		50 - 200
13C8 PFOA	107		50 - 200
13C9 PFNA	108		50 - 200
13C7 PFUnA	107		50 - 200
13C2 PFDoA	103		50 - 200
13C4 PFBA	106		50 - 200
13C5 PFPeA	107		50 - 200
13C3 PFBS	107		50 - 200
13C3 PFHxS	113		50 - 200
13C8 PFOS	107		50 - 200
13C2-4:2-FTS	110		50 - 200
13C2-6:2-FTS	104		50 - 200
13C2-8:2-FTS	107		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-204090/19-A
Matrix: Water
Analysis Batch: 204365

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 204090

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Perfluorotridecanoic acid (PFTTrDA)	<0.36		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	<0.30		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		02/06/26 15:29	02/09/26 07:20	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	106		70 - 130			02/06/26 15:29	02/09/26 07:20	1
13C2 PFHxA	110		70 - 130			02/06/26 15:29	02/09/26 07:20	1
13C2 PFDA	128		70 - 130			02/06/26 15:29	02/09/26 07:20	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-204090/19-A

Matrix: Water

Analysis Batch: 204365

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 204090

Surrogate	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3-GenX	104		70 - 130	02/06/26 15:29	02/09/26 07:20	1

Lab Sample ID: LCS 380-204090/21-A

Matrix: Water

Analysis Batch: 204365

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 204090

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	50.1	46.8		ng/L		93	70 - 130
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	50.1	52.0		ng/L		104	70 - 130
Perfluoroundecanoic acid (PFUnA)	50.1	55.0		ng/L		110	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	50.1	46.6		ng/L		93	70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	50.1	45.9		ng/L		92	70 - 130
Perfluorohexanoic acid (PFHxA)	50.1	49.6		ng/L		99	70 - 130
Perfluorododecanoic acid (PFDoA)	50.1	54.4		ng/L		109	70 - 130
Perfluorooctanoic acid (PFOA)	50.1	50.0		ng/L		100	70 - 130
Perfluorodecanoic acid (PFDA)	50.1	51.8		ng/L		103	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	50.1	52.0		ng/L		104	70 - 130
Perfluorobutanesulfonic acid (PFBS)	50.1	53.2		ng/L		106	70 - 130
Perfluoroheptanoic acid (PFHpA)	50.1	49.4		ng/L		99	70 - 130
Perfluorononanoic acid (PFNA)	50.1	52.5		ng/L		105	70 - 130
Perfluorotetradecanoic acid (PFTA)	50.1	52.3		ng/L		104	70 - 130
Perfluorotridecanoic acid (PFTrDA)	50.1	55.6		ng/L		111	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	50.1	53.3		ng/L		106	70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	50.1	53.6		ng/L		107	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	50.1	47.5		ng/L		95	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
d5-NEtFOSAA	101		70 - 130
13C2 PFHxA	108		70 - 130
13C2 PFDA	120		70 - 130
13C3-GenX	106		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-204090/20-A

Matrix: Water

Analysis Batch: 204365

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 204090

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	2.00	1.83	J	ng/L		92	50 - 150
Dimer Acid (HFPO-DA/GenX)							
Perfluorooctanesulfonic acid (PFOS)	2.00	2.21	J	ng/L		110	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.31	J	ng/L		115	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.00	1.81	J	ng/L		90	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.00	1.83	J	ng/L		91	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	2.00	J	ng/L		100	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	2.32	J	ng/L		116	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	1.95	J	ng/L		97	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.08	J	ng/L		104	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	2.31	J	ng/L		115	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	2.21	J	ng/L		111	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	1.90	J	ng/L		95	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.19	J	ng/L		109	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.00	2.30	J	ng/L		115	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.00	2.42	J	ng/L		121	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	2.26	J	ng/L		113	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	2.19	J	ng/L		109	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	1.97	J	ng/L		98	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	97		70 - 130
13C2 PFHxA	106		70 - 130
13C2 PFDA	119		70 - 130
13C3-GenX	100		70 - 130

Lab Sample ID: 380-195691-B-1-A MS

Matrix: Water

Analysis Batch: 204365

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 204090

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		25.2	29.2		ng/L		116	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorooctanesulfonic acid (PFOS)	<2.0		25.2	27.1		ng/L		105	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		25.2	27.4		ng/L		109	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		25.2	26.4		ng/L		105	70 - 130

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-195691-B-1-A MS

Matrix: Water

Analysis Batch: 204365

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 204090

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	Limits		
	Result	Qualifier	Added	Result	Qualifier			%Rec			
N-ethylperfluorooctanesulfonami doacetic acid (NEtFOSAA)	<2.0		25.2	25.9		ng/L		103	70 - 130		
Perfluorohexanoic acid (PFHxA)	<2.0		25.2	29.9		ng/L		112	70 - 130		
Perfluorododecanoic acid (PFDoA)	<2.0		25.2	28.6		ng/L		114	70 - 130		
Perfluorooctanoic acid (PFOA)	<2.0		25.2	27.3		ng/L		106	70 - 130		
Perfluorodecanoic acid (PFDA)	<2.0		25.2	27.6		ng/L		110	70 - 130		
Perfluorohexanesulfonic acid (PFHxS)	5.0		25.2	32.1		ng/L		108	70 - 130		
Perfluorobutanesulfonic acid (PFBS)	<2.0		25.2	29.3		ng/L		110	70 - 130		
Perfluoroheptanoic acid (PFHpA)	<2.0		25.2	27.7		ng/L		110	70 - 130		
Perfluorononanoic acid (PFNA)	<2.0		25.2	27.7		ng/L		110	70 - 130		
Perfluorotetradecanoic acid (PFTA)	<2.0		25.2	28.8		ng/L		114	70 - 130		
Perfluorotridecanoic acid (PFTrDA)	<2.0		25.2	30.4		ng/L		121	70 - 130		
9-Chlorohexadecafluoro-3-oxan onane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		25.2	27.3		ng/L		109	70 - 130		
11-Chloroeicosafluoro-3-oxaund ecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		25.2	27.4		ng/L		109	70 - 130		
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		25.2	29.1		ng/L		116	70 - 130		
		MS			MS						
Surrogate	%Recovery	Qualifier	Limits								
d5-NEtFOSAA	112		70 - 130								
13C2 PFHxA	123		70 - 130								
13C2 PFDA	119		70 - 130								
13C3-GenX	121		70 - 130								

Lab Sample ID: 380-195691-C-1-A MSD

Matrix: Water

Analysis Batch: 204365

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 204090

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		25.2	29.3		ng/L		116	70 - 130	0	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		25.2	27.2		ng/L		106	70 - 130	0	30
Perfluoroundecanoic acid (PFUnA)	<2.0		25.2	27.3		ng/L		109	70 - 130	0	30
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		25.2	25.8		ng/L		103	70 - 130	2	30
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		25.2	25.0		ng/L		100	70 - 130	3	30
Perfluorohexanoic acid (PFHxA)	<2.0		25.2	31.0		ng/L		116	70 - 130	4	30
Perfluorododecanoic acid (PFDoA)	<2.0		25.2	28.9		ng/L		115	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	<2.0		25.2	26.8		ng/L		104	70 - 130	2	30
Perfluorodecanoic acid (PFDA)	<2.0		25.2	27.6		ng/L		110	70 - 130	0	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: 380-195691-C-1-A MSD

Matrix: Water

Analysis Batch: 204365

Client Sample ID: Matrix Spike Duplicate

Prep Type: Total/NA

Prep Batch: 204090

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Perfluorohexanesulfonic acid (PFHxS)	5.0		25.2	31.9		ng/L		107	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		25.2	29.6		ng/L		112	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0		25.2	27.1		ng/L		108	70 - 130	2	30
Perfluorononanoic acid (PFNA)	<2.0		25.2	27.9		ng/L		111	70 - 130	0	30
Perfluorotetradecanoic acid (PFTA)	<2.0		25.2	29.0		ng/L		115	70 - 130	1	30
Perfluorotridecanoic acid (PFTrDA)	<2.0		25.2	29.8		ng/L		118	70 - 130	2	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		25.2	27.3		ng/L		109	70 - 130	0	30
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		25.2	27.3		ng/L		109	70 - 130	0	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		25.2	27.4		ng/L		109	70 - 130	6	30
Surrogate	MSD %Recovery	MSD Qualifier	Limits								
d5-NEtFOSAA	107		70 - 130								
13C2 PFHxA	119		70 - 130								
13C2 PFDA	119		70 - 130								
13C3-GenX	123		70 - 130								

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

LCMS

Prep Batch: 204090

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-196035-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	537.1 DW	
380-196035-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	537.1 DW	
MBL 380-204090/19-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-204090/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-204090/20-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-195691-B-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-195691-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

Analysis Batch: 204365

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-196035-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	EPA 537.1 V2	204090
380-196035-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	EPA 537.1 V2	204090
MBL 380-204090/19-A	Method Blank	Total/NA	Water	EPA 537.1 V2	204090
LCS 380-204090/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	204090
MRL 380-204090/20-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	204090
380-195691-B-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	204090
380-195691-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	204090

Prep Batch: 204366

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-196035-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	533	
380-196035-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	533	
MBL 380-204366/20-A	Method Blank	Total/NA	Water	533	
LCS 380-204366/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-204366/21-A	Lab Control Sample	Total/NA	Water	533	
380-196010-E-1-A MS	Matrix Spike	Total/NA	Water	533	
380-196010-F-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 204503

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-196035-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	533	204366
380-196035-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Water	533	204366
MBL 380-204366/20-A	Method Blank	Total/NA	Water	533	204366
LCS 380-204366/22-A	Lab Control Sample	Total/NA	Water	533	204366
MRL 380-204366/21-A	Lab Control Sample	Total/NA	Water	533	204366
380-196010-E-1-A MS	Matrix Spike	Total/NA	Water	533	204366
380-196010-F-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	204366

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

**Client Sample ID: AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-196035-1

Date Collected: 02/02/26 11:39

Matrix: Drinking Water

Date Received: 02/04/26 09:22

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			204366	XTD8	EA POM	02/09/26 06:54
Total/NA	Analysis	533		1	204503	M7ML	EA POM	02/09/26 20:05
Total/NA	Prep	537.1 DW			204090	N8NE	EA POM	02/06/26 15:29
Total/NA	Analysis	EPA 537.1 V2		1	204365	M7ML	EA POM	02/09/26 10:23

**Client Sample ID: FB AIEA GULCH WELLS PUMP 2
(331-202-TP072)**

Lab Sample ID: 380-196035-2

Date Collected: 02/02/26 11:39

Matrix: Water

Date Received: 02/04/26 09:22

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			204366	XTD8	EA POM	02/09/26 06:54
Total/NA	Analysis	533		1	204503	M7ML	EA POM	02/09/26 20:15
Total/NA	Prep	537.1 DW			204090	N8NE	EA POM	02/06/26 15:29
Total/NA	Analysis	EPA 537.1 V2		1	204365	M7ML	EA POM	02/09/26 10:32

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-196035-1
SDG: PFAS: Aiea Gulch Wells Pump 2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-196035-1	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Drinking Water	02/02/26 11:39	02/04/26 09:22	Hawaii
380-196035-2	FB AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Water	02/02/26 11:39	02/04/26 09:22	Hawaii

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

Ver: 01/16/2019

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-196035-1

SDG Number: PFAS: Aiea Gulch Wells Pump 2

Login Number: 196035

List Number: 1

Creator: Ngo, Theodore

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	