

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16

# ANALYTICAL REPORT

## PREPARED FOR

Attn: Mr. Erwin Kawata  
City & County of Honolulu  
630 South Beretania Street  
Public Service Bldg. Room 310  
Honolulu, Hawaii 96843

Generated 1/20/2026 4:26:50 PM

## JOB DESCRIPTION

RED-HILL  
Weekly: Aiea Gulch Pump 1/Pump2

## JOB NUMBER

380-189450-1

# Eurofins Pomona

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

## Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

## Authorization



Authorized for release by  
Maria Lopez, Project Manager  
[Maria.Lopez@et.eurofinsus.com](mailto:Maria.Lopez@et.eurofinsus.com)  
(626)386-1100

Generated  
1/20/2026 4:26:50 PM



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	5
Detection Summary . . . . .	6
Client Sample Results . . . . .	7
Action Limit Summary . . . . .	13
Surrogate Summary . . . . .	14
QC Sample Results . . . . .	17
QC Association Summary . . . . .	32
Lab Chronicle . . . . .	34
Certification Summary . . . . .	35
Method Summary . . . . .	37
Sample Summary . . . . .	38
Chain of Custody . . . . .	39
Receipt Checklists . . . . .	42

# Definitions/Glossary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Qualifiers

### GC/MS Semi VOA

Qualifier	Qualifier Description
^3+	Reporting Limit Check Standard is outside acceptance limits, high biased
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

### GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

### GC VOA

Qualifier	Qualifier Description
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

### GC Semi VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
S1+	Surrogate recovery exceeds control limits, high biased.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: City & County of Honolulu  
Project: RED-HILL

Job ID: 380-189450-1

Job ID: 380-189450-1

Eurofins Pomona

## Job Narrative 380-189450-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

### Receipt

The samples were received on 12/24/2025 10:37 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 0.7°C.

### GC/MS Semi VOA

Method 625.1 and 625.1\_SIM: The following sample was re-prepared outside of preparation holding time due to accidental spike in original prep: AIEA GULCH WELLS PUMP 1 (331-201-TP071) (380-189450-1). Analysis for 625.1 and 625.1\_SIM for AIEA GULCH WELLS PUMP 1 (331-201-TP071) (380-189450-1) is not acceptable for reporting purpose due to this accidental spike of the sample, analysis for 625.1 and 625.1\_SIM will be canceled. The sample is collected weekly thus follow up sample was collected on 01/05/26 under job # 380-190897-1. Analysis for 625.1 and 625.1\_SIM is currently in progress. (XWB4)

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Gasoline Range Organics

Method 8015B\_GRO\_LL: The matrix spike duplicate (MSD) recovery for analytical batch 570-678421 was outside control limits for Gasoline Range Organics (C4-C13). See QC Sample Results for detail. Sample matrix interference and/or non-homogeneity are suspected because the associated laboratory control sample (LCS) and laboratory control sample duplicate (LCSD) recoveries were within acceptance limits.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Diesel Range Organics

Method 8015B\_DRO\_LL\_CS: Surrogate recovery was outside acceptance limits for the following matrix spike duplicate (MSD) sample: (380-189454-A-1-B MSD). The parent sample's surrogate recovery was within limits. The MSD sample has been qualified and reported.

Method 8015B\_DRO\_LL\_CS: The laboratory control sample (LCS) for preparation batch 570-675474 and analytical batch 570-679396 recovered outside control limits for the following analytes: n-Octacosane (Surr). These analytes were biased high in the LCS and were not detected in the associated samples; therefore, the data have been reported.

Method 8015B\_DRO\_LL\_CS: The method reporting limit check (MRL) for preparation batch 570-675474 and analytical batch 570-679714 recovered outside control limits for the following analytes: n-Octacosane (Surr). These analytes were biased high in the MRL and were not detected in the associated samples; therefore, the data have been reported.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

# Detection Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-189450-1**

No Detections.

**Client Sample ID: TB: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-189450-2**

No Detections.

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-189450-3**

No Detections.

**Client Sample ID: TB: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-189450-4**

No Detections.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

This Detection Summary does not include radiochemical test results.

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-189450-1**

**Date Collected: 12/22/25 09:00**

**Matrix: Drinking Water**

**Date Received: 12/24/25 10:37**

**Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
2,4'-DDD	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
2,4'-DDE	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
2,4'-DDT	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
2,4-Dinitrotoluene	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
2,6-Dinitrotoluene	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
2-Methylnaphthalene	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
4,4'-DDD	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
4,4'-DDE	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
4,4'-DDT	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Acenaphthene	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Acenaphthylene	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Acetochlor	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Alachlor	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
alpha-BHC	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
alpha-Chlordane	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Anthracene	<0.019		0.019	ug/L		12/30/25 15:37	12/31/25 18:48	1
Atrazine	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Benz(a)anthracene	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Benzo[a]pyrene	<0.019		0.019	ug/L		12/30/25 15:37	12/31/25 18:48	1
Benzo[b]fluoranthene	<0.019		0.019	ug/L		12/30/25 15:37	12/31/25 18:48	1
Benzo[g,h,i]perylene	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Benzo[k]fluoranthene	<0.019		0.019	ug/L		12/30/25 15:37	12/31/25 18:48	1
beta-BHC	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Bis(2-ethylhexyl) phthalate	<0.58		0.58	ug/L		12/30/25 15:37	12/31/25 18:48	1
Bromacil	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Butachlor	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Butylbenzylphthalate	<0.48		0.48	ug/L		12/30/25 15:37	12/31/25 18:48	1
Chlorobenzilate	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Chloroneb	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Chlorothalonil (Draconil, Bravo)	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Chlorpyrifos	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Chrysene	<0.019		0.019	ug/L		12/30/25 15:37	12/31/25 18:48	1
delta-BHC	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Di(2-ethylhexyl)adipate	<0.58		0.58	ug/L		12/30/25 15:37	12/31/25 18:48	1
Dibenz(a,h)anthracene	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Diclorvos (DDVP)	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Dieldrin	<0.0096		0.0096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Diethylphthalate	<0.48		0.48	ug/L		12/30/25 15:37	12/31/25 18:48	1
Dimethylphthalate	<0.48		0.48	ug/L		12/30/25 15:37	12/31/25 18:48	1
Di-n-butyl phthalate	<0.96		0.96	ug/L		12/30/25 15:37	12/31/25 18:48	1
Di-n-octyl phthalate	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Endosulfan I (Alpha)	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Endosulfan II (Beta)	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Endosulfan sulfate	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Endrin	<0.0096		0.0096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Endrin aldehyde	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
EPTC	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-189450-1**

**Date Collected: 12/22/25 09:00**

**Matrix: Drinking Water**

**Date Received: 12/24/25 10:37**

**Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Fluorene	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
gamma-Chlordane	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Heptachlor	<0.0096		0.0096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Heptachlor epoxide (isomer B)	<0.0096	^3+	0.0096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Hexachlorobenzene	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Hexachlorocyclopentadiene	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Indeno[1,2,3-cd]pyrene	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Isophorone	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Lindane	<0.0096		0.0096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Malathion	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Methoxychlor	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Metolachlor	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Molinate	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Naphthalene	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Parathion	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Pendimethalin (Penoxaline)	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Phenanthrene	<0.039		0.039	ug/L		12/30/25 15:37	12/31/25 18:48	1
Propachlor	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Pyrene	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Simazine	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Terbacil	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Terbutylazine	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Thiobencarb	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1
Total Permethrin (mixed isomers)	<0.19		0.19	ug/L		12/30/25 15:37	12/31/25 18:48	1
trans-Nonachlor	<0.048		0.048	ug/L		12/30/25 15:37	12/31/25 18:48	1
Trifluralin	<0.096		0.096	ug/L		12/30/25 15:37	12/31/25 18:48	1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	12/30/25 15:37	12/31/25 18:48	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	96		70 - 130	12/30/25 15:37	12/31/25 18:48	1
Perylene-d12	91		70 - 130	12/30/25 15:37	12/31/25 18:48	1
Triphenylphosphate	106		70 - 130	12/30/25 15:37	12/31/25 18:48	1

**Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			12/28/25 23:04	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	101		38 - 134		12/28/25 23:04	1

**Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level - RA**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25	ug/L		12/27/25 09:07	01/07/26 18:34	1
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		12/27/25 09:07	01/07/26 18:34	1
C8-C18	<25		25	ug/L		12/27/25 09:07	01/07/26 18:34	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-189450-1**

Date Collected: 12/22/25 09:00  
Date Received: 12/24/25 10:37

Matrix: Drinking Water

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
<i>n</i> -Octacosane (Surr)	129		60 - 130	12/27/25 09:07	01/07/26 18:34	1

**Client Sample ID: TB: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-189450-2**

Date Collected: 12/22/25 09:00  
Date Received: 12/24/25 10:37

Matrix: Water

**Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<0.10		10	ug/L	-		01/05/26 00:09	1
Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac		
4-Bromofluorobenzene (Surr)	107		38 - 134			01/05/26 00:09	1	

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-189450-3**

Date Collected: 12/22/25 09:00  
Date Received: 12/24/25 10:37

Matrix: Drinking Water

**Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
2,4'-DDD	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
2,4'-DDE	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
2,4'-DDT	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
2,4-Dinitrotoluene	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
2,6-Dinitrotoluene	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
2-Methylnaphthalene	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
4,4'-DDD	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
4,4'-DDE	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
4,4'-DDT	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Acenaphthene	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Acenaphthylene	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Acetochlor	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Alachlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
alpha-BHC	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
alpha-Chlordane	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Anthracene	<0.019		0.019	ug/L		12/30/25 15:37	12/31/25 19:08	1
Atrazine	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Benz(a)anthracene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Benzo[a]pyrene	<0.019		0.019	ug/L		12/30/25 15:37	12/31/25 19:08	1
Benzo[b]fluoranthene	<0.019		0.019	ug/L		12/30/25 15:37	12/31/25 19:08	1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Benzo[k]fluoranthene	<0.019		0.019	ug/L		12/30/25 15:37	12/31/25 19:08	1
beta-BHC	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Bis(2-ethylhexyl) phthalate	<0.58		0.58	ug/L		12/30/25 15:37	12/31/25 19:08	1
Bromacil	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Butachlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Butylbenzylphthalate	<0.49		0.49	ug/L		12/30/25 15:37	12/31/25 19:08	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-189450-3**

**Date Collected: 12/22/25 09:00**

**Matrix: Drinking Water**

**Date Received: 12/24/25 10:37**

**Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Chlorobenzilate	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Chloroneb	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Chlorothalonil (Draconil, Bravo)	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Chlorpyrifos	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Chrysene	<0.019		0.019	ug/L		12/30/25 15:37	12/31/25 19:08	1
delta-BHC	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Di(2-ethylhexyl)adipate	<0.58		0.58	ug/L		12/30/25 15:37	12/31/25 19:08	1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Diclorvos (DDVP)	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Dieldrin	<0.0097		0.0097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Diethylphthalate	<0.49		0.49	ug/L		12/30/25 15:37	12/31/25 19:08	1
Dimethylphthalate	<0.49		0.49	ug/L		12/30/25 15:37	12/31/25 19:08	1
Di-n-butyl phthalate	<0.97		0.97	ug/L		12/30/25 15:37	12/31/25 19:08	1
Di-n-octyl phthalate	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Endosulfan I (Alpha)	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Endosulfan II (Beta)	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Endosulfan sulfate	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Endrin	<0.0097		0.0097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Endrin aldehyde	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
EPTC	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Fluoranthene	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Fluorene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
gamma-Chlordane	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Heptachlor	<0.0097		0.0097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Heptachlor epoxide (isomer B)	<0.0097	^3+	0.0097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Hexachlorobenzene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Hexachlorocyclopentadiene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Isophorone	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Lindane	<0.0097		0.0097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Malathion	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Methoxychlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Metolachlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Molinate	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Naphthalene	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Parathion	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Pendimethalin (Penoxaline)	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Phenanthrene	<0.039		0.039	ug/L		12/30/25 15:37	12/31/25 19:08	1
Propachlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Pyrene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Simazine	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Terbacil	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Terbutylazine	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Thiobencarb	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1
Total Permethrin (mixed isomers)	<0.19		0.19	ug/L		12/30/25 15:37	12/31/25 19:08	1
trans-Nonachlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 19:08	1
Trifluralin	<0.097		0.097	ug/L		12/30/25 15:37	12/31/25 19:08	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-189450-3**

**Date Collected: 12/22/25 09:00**

**Matrix: Drinking Water**

**Date Received: 12/24/25 10:37**

<i>Tentatively Identified Compound</i>	<i>Est. Result</i>	<i>Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>RT</i>	<i>CAS No.</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
<i>Tentatively Identified Compound</i>	<i>None</i>		<i>ug/L</i>			<i>N/A</i>	<i>12/30/25 15:37</i>	<i>12/31/25 19:08</i>	<i>1</i>
<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>				<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
<i>2-Nitro-m-xylene</i>	<i>97</i>		<i>70 - 130</i>				<i>12/30/25 15:37</i>	<i>12/31/25 19:08</i>	<i>1</i>
<i>Perylene-d12</i>	<i>81</i>		<i>70 - 130</i>				<i>12/30/25 15:37</i>	<i>12/31/25 19:08</i>	<i>1</i>
<i>Triphenylphosphate</i>	<i>107</i>		<i>70 - 130</i>				<i>12/30/25 15:37</i>	<i>12/31/25 19:08</i>	<i>1</i>

**Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)**

<i>Analyte</i>	<i>Result</i>	<i>Qualifier</i>	<i>RL</i>	<i>Unit</i>	<i>D</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
<i>1-Methylnaphthalene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>2-Methylnaphthalene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Acenaphthene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Acenaphthylene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Anthracene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Benzo[a]anthracene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Benzo[a]pyrene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Benzo[b]fluoranthene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Benzo[g,h,i]perylene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Benzo[k]fluoranthene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Chrysene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Dibenz(a,h)anthracene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Fluoranthene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Fluorene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Indeno[1,2,3-cd]pyrene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Naphthalene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Phenanthrene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Pyrene</i>	<i>&lt;0.19</i>		<i>0.19</i>	<i>ug/L</i>		<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>

<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
<i>2,4,6-Tribromophenol (Surr)</i>	<i>89</i>		<i>28 - 127</i>	<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>2-Fluorobiphenyl (Surr)</i>	<i>93</i>		<i>31 - 120</i>	<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>2-Fluorophenol (Surr)</i>	<i>59</i>		<i>17 - 120</i>	<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Nitrobenzene-d5 (Surr)</i>	<i>96</i>		<i>27 - 120</i>	<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>Phenol-d6 (Surr)</i>	<i>37</i>		<i>10 - 120</i>	<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>
<i>p-Terphenyl-d14 (Surr)</i>	<i>92</i>		<i>45 - 120</i>	<i>12/27/25 08:18</i>	<i>01/07/26 14:19</i>	<i>1</i>

**Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)**

<i>Tentatively Identified Compound</i>	<i>Est. Result</i>	<i>Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>RT</i>	<i>CAS No.</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
<i>Tentatively Identified Compound</i>	<i>None</i>		<i>ug/L</i>			<i>N/A</i>	<i>12/27/25 08:18</i>	<i>01/12/26 14:48</i>	<i>1</i>
<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>			
<i>2,4,6-Tribromophenol (Surr)</i>	<i>75</i>		<i>33 - 139</i>	<i>12/27/25 08:18</i>	<i>01/12/26 14:48</i>	<i>1</i>			
<i>2-Fluorobiphenyl (Surr)</i>	<i>101</i>		<i>33 - 126</i>	<i>12/27/25 08:18</i>	<i>01/12/26 14:48</i>	<i>1</i>			
<i>2-Fluorophenol (Surr)</i>	<i>64</i>		<i>12 - 120</i>	<i>12/27/25 08:18</i>	<i>01/12/26 14:48</i>	<i>1</i>			
<i>Nitrobenzene-d5 (Surr)</i>	<i>111</i>		<i>36 - 120</i>	<i>12/27/25 08:18</i>	<i>01/12/26 14:48</i>	<i>1</i>			
<i>Phenol-d6 (Surr)</i>	<i>39</i>		<i>10 - 120</i>	<i>12/27/25 08:18</i>	<i>01/12/26 14:48</i>	<i>1</i>			
<i>p-Terphenyl-d14 (Surr)</i>	<i>102</i>		<i>47 - 131</i>	<i>12/27/25 08:18</i>	<i>01/12/26 14:48</i>	<i>1</i>			

# Client Sample Results

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-189450-1  
 SDG: Weekly: Aiea Gulch Pump 1/Pump2

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
 (331-202-TP072)**

**Lab Sample ID: 380-189450-3**

Date Collected: 12/22/25 09:00

Matrix: Drinking Water

Date Received: 12/24/25 10:37

**Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			01/04/26 20:28	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	106		38 - 134				01/04/26 20:28	1

**Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level - RA**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<26		26	ug/L		12/27/25 09:07	01/07/26 18:55	1
Motor Oil Range Organics [C24-C36]	<26		26	ug/L		12/27/25 09:07	01/07/26 18:55	1
C8-C18	<26		26	ug/L		12/27/25 09:07	01/07/26 18:55	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)	125		60 - 130			12/27/25 09:07	01/07/26 18:55	1

**Client Sample ID: TB: AIEA GULCH WELLS PUMP 2  
 (331-202-TP072)**

**Lab Sample ID: 380-189450-4**

Date Collected: 12/22/25 09:00

Matrix: Water

Date Received: 12/24/25 10:37

**Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			12/28/25 20:52	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	102		38 - 134				12/28/25 20 52	1

# Action Limit Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-189450-1**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Alachlor	<0.048		ug/L	2	0.048	525.2	Total/NA
Atrazine	<0.048		ug/L	3	0.048	525.2	Total/NA
Benzo[a]pyrene	<0.019		ug/L	0.2	0.019	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.58		ug/L	6	0.58	525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.58		ug/L	400	0.58	525.2	Total/NA
Endrin	<0.0096		ug/L	2	0.0096	525.2	Total/NA
Heptachlor	<0.0096		ug/L	0.4	0.0096	525.2	Total/NA
Heptachlor epoxide (isomer B)	<0.0096	^3+	ug/L	0.2	0.0096	525.2	Total/NA
Hexachlorobenzene	<0.048		ug/L	1	0.048	525.2	Total/NA
Hexachlorocyclopentadiene	<0.048		ug/L	50	0.048	525.2	Total/NA
Lindane	<0.0096		ug/L	0.2	0.0096	525.2	Total/NA
Methoxychlor	<0.048		ug/L	40	0.048	525.2	Total/NA
Simazine	<0.048		ug/L	4	0.048	525.2	Total/NA

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-189450-3**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Alachlor	<0.049		ug/L	2	0.049	525.2	Total/NA
Atrazine	<0.049		ug/L	3	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.019		ug/L	0.2	0.019	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.58		ug/L	6	0.58	525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.58		ug/L	400	0.58	525.2	Total/NA
Endrin	<0.0097		ug/L	2	0.0097	525.2	Total/NA
Heptachlor	<0.0097		ug/L	0.4	0.0097	525.2	Total/NA
Heptachlor epoxide (isomer B)	<0.0097	^3+	ug/L	0.2	0.0097	525.2	Total/NA
Hexachlorobenzene	<0.049		ug/L	1	0.049	525.2	Total/NA
Hexachlorocyclopentadiene	<0.049		ug/L	50	0.049	525.2	Total/NA
Lindane	<0.0097		ug/L	0.2	0.0097	525.2	Total/NA
Methoxychlor	<0.049		ug/L	40	0.049	525.2	Total/NA
Simazine	<0.049		ug/L	4	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.19		ug/L	0.2	0.19	625.1 SIM	Total/NA

# Surrogate Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-189450-1	AIEA GULCH WELLS PUMP 1 (	96	91	106
380-189450-3	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	97	81	107

**Surrogate Legend**  
 2NMX = 2-Nitro-m-xylene  
 PRY = Perylene d12  
 TPP = Triphenylphosphate

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-189454-I-1-A MS	Matrix Spike	96	104	107
380-189454-J-1-A MSD	Matrix Spike Duplicate	97	105	108
LCS 380-195112/22-A	Lab Control Sample	95	101	106
MB 380-195112/20-A	Method Blank	96	83	107
MRL 380-195112/21-A	Lab Control Sample	95	88	104

**Surrogate Legend**  
 2NMX = 2-Nitro-m-xylene  
 PRY = Perylene-d12  
 TPP = Triphenylphosphate

## Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)
380-189450-3	AIEA GULCH WELLS PUMP 2 (	75	101	64	111	39	102

**Surrogate Legend**  
 TBP = 2,4,6-Tribromophenol (Surr)  
 FBP = 2-Fluorobiphenyl (Surr)  
 2FP = 2-Fluorophenol (Surr)  
 NBZ = Nitrobenzene-d5 (Surr)  
 PHL6 = Phenol-d6 (Surr)  
 TPHd14 = p-Terphenyl-d14 (Surr)

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-189450-3	AIEA GULCH WELLS PUMP 2 (	89	93	59	96	37	92

**Surrogate Legend**  
 TBP = 2,4,6-Tribromophenol (Surr)  
 FBP = 2-Fluorobiphenyl (Surr)

# Surrogate Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-189450-1  
 SDG: Weekly: Aiea Gulch Pump 1/Pump2

2FP = 2-Fluorophenol (Surr)  
 NBZ = Nitrobenzene-d5 (Surr)  
 PHL6 = Phenol-d6 (Surr)  
 TPHd14 = p-Terphenyl-d14 (Surr)

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
LCS 570-675514/2-A	Lab Control Sample	46	43	32	38	21	50
LCSD 570-675514/3-A	Lab Control Sample Dup	43	43	32	37	21	49
MB 570-675514/1-A	Method Blank	89	83	61	89	38	93

### Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)  
 FBP = 2-Fluorobiphenyl (Surr)  
 2FP = 2-Fluorophenol (Surr)  
 NBZ = Nitrobenzene-d5 (Surr)  
 PHL6 = Phenol-d6 (Surr)  
 TPHd14 = p-Terphenyl-d14 (Surr)

## Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)
		BFB1 (38-134)
380-189450-1	AIEA GULCH WELLS PUMP 1 (	101
380-189450-3	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	106

### Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

## Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)
		BFB1 (38-134)
380-189446-E-1 MS	Matrix Spike	103
380-189446-E-1 MSD	Matrix Spike Duplicate	101
380-189450-2	TB: AIEA GULCH WELLS PUMF 1 (331-201-TP071)	107
380-189450-4	TB: AIEA GULCH WELLS PUMF 2 (331-202-TP072)	102
380-190087-C-1 MS	Matrix Spike	102
380-190087-C-1 MSD	Matrix Spike Duplicate	107
LCS 570-675935/4	Lab Control Sample	100
LCS 570-678421/1011	Lab Control Sample	91
LCSD 570-675935/5	Lab Control Sample Dup	105
LCSD 570-678421/12	Lab Control Sample Dup	94
MB 570-675935/6	Method Blank	101
MB 570-678421/13	Method Blank	98
MRL 570-675935/3	Lab Control Sample	93
MRL 570-678421/14	Lab Control Sample	94

### Surrogate Legend

Eurofins Pomona

# Surrogate Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL  
 BFB = 4-Bromofluorobenzene (Surr)

Job ID: 380-189450-1  
 SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Drinking Water

Prep Type: Total/NA

### Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-189450-1 - RA	AIEA GULCH WELLS PUMP 1 (	129
380-189450-3 - RA	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	125

**Surrogate Legend**

OTCSN = n-Octacosane (Surr)

## Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water

Prep Type: Total/NA

### Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-189454-A-1-A MS	Matrix Spike	116
380-189454-A-1-B MSD	Matrix Spike Duplicate	144 S1+
LCS 570-675474/2-A	Lab Control Sample	131 S1+
LCSD 570-675474/3-A	Lab Control Sample Dup	112
MB 570-675474/1-A	Method Blank	97
MRL 570-675474/4-A	Lab Control Sample	153

**Surrogate Legend**

OTCSN = n-Octacosane (Surr)

# QC Sample Results

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-189450-1  
 SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

**Lab Sample ID: MB 380-195112/20-A**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
2,4'-DDD	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
2,4'-DDE	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
2,4'-DDT	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
2,4-Dinitrotoluene	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
2,6-Dinitrotoluene	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
2-Methylnaphthalene	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
4,4'-DDD	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
4,4'-DDE	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
4,4'-DDT	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Acenaphthene	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Acenaphthylene	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Acetochlor	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Alachlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
alpha-BHC	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
alpha-Chlordane	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Anthracene	<0.020		0.020	ug/L		12/30/25 15:37	12/31/25 15:28	1
Atrazine	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Benz(a)anthracene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Benzo[a]pyrene	<0.020		0.020	ug/L		12/30/25 15:37	12/31/25 15:28	1
Benzo[b]fluoranthene	<0.020		0.020	ug/L		12/30/25 15:37	12/31/25 15:28	1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Benzo[k]fluoranthene	<0.020		0.020	ug/L		12/30/25 15:37	12/31/25 15:28	1
beta-BHC	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Bis(2-ethylhexyl) phthalate	<0.59		0.59	ug/L		12/30/25 15:37	12/31/25 15:28	1
Bromacil	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Butachlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Butylbenzylphthalate	<0.49		0.49	ug/L		12/30/25 15:37	12/31/25 15:28	1
Chlorobenzilate	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Chloroneb	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Chlorothalonil (Draconil, Bravo)	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Chlorpyrifos	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Chrysene	<0.020		0.020	ug/L		12/30/25 15:37	12/31/25 15:28	1
delta-BHC	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Di(2-ethylhexyl)adipate	<0.59		0.59	ug/L		12/30/25 15:37	12/31/25 15:28	1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Diclorvos (DDVP)	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Dieldrin	<0.0099		0.0099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Diethylphthalate	<0.49		0.49	ug/L		12/30/25 15:37	12/31/25 15:28	1
Dimethylphthalate	<0.49		0.49	ug/L		12/30/25 15:37	12/31/25 15:28	1
Di-n-butyl phthalate	<0.99		0.99	ug/L		12/30/25 15:37	12/31/25 15:28	1
Di-n-octyl phthalate	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Endosulfan I (Alpha)	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Endosulfan II (Beta)	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Endosulfan sulfate	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Endrin	<0.0099		0.0099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Endrin aldehyde	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
EPTC	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: MB 380-195112/20-A**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Fluorene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
gamma-Chlordane	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Heptachlor	<0.0099		0.0099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Heptachlor epoxide (isomer B)	<0.0099	^3+	0.0099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Hexachlorobenzene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Hexachlorocyclopentadiene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Isophorone	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Lindane	<0.0099		0.0099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Malathion	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Methoxychlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Metolachlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Molinate	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Naphthalene	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Parathion	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Pendimethalin (Penoxaline)	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Phenanthrene	<0.040		0.040	ug/L		12/30/25 15:37	12/31/25 15:28	1
Propachlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Pyrene	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Simazine	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Terbacil	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Terbutylazine	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Thiobencarb	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1
Total Permethrin (mixed isomers)	<0.20		0.20	ug/L		12/30/25 15:37	12/31/25 15:28	1
trans-Nonachlor	<0.049		0.049	ug/L		12/30/25 15:37	12/31/25 15:28	1
Trifluralin	<0.099		0.099	ug/L		12/30/25 15:37	12/31/25 15:28	1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Cyclopentene, 1,2,3,4,5-pentamethyl-	1.47	T J N	ug/L		2.54	1000154-28-6	12/30/25 15:37	12/31/25 15:28	1
Undecane	2.77	T J N	ug/L		3.14	1120-21-4	12/30/25 15:37	12/31/25 15:28	1
Plumbane, diethyldimethyl-	0.797	T J N	ug/L		3.27	1762-27-2	12/30/25 15:37	12/31/25 15:28	1
Cyclohexasiloxane, dodecamethyl-	0.685	T J N	ug/L		3.90	540-97-6	12/30/25 15:37	12/31/25 15:28	1
Hexadecanamide	0.782	T J N	ug/L		7.08	629-54-9	12/30/25 15:37	12/31/25 15:28	1
9-Octadecenamide, (Z)-	8.70	T J N	ug/L		7.97	301-02-0	12/30/25 15:37	12/31/25 15:28	1
Tetradecanamide	0.537	T J N	ug/L		8.07	638-58-4	12/30/25 15:37	12/31/25 15:28	1
13-Docosenamide, (Z)-	1.26	T J N	ug/L		10.53	112-84-5	12/30/25 15:37	12/31/25 15:28	1
Unknown	0.530	T J	ug/L		15.13	N/A	12/30/25 15:37	12/31/25 15:28	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	96		70 - 130	12/30/25 15:37	12/31/25 15:28	1
Perylene-d12	83		70 - 130	12/30/25 15:37	12/31/25 15:28	1
Triphenylphosphate	107		70 - 130	12/30/25 15:37	12/31/25 15:28	1

# QC Sample Results

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-189450-1  
 SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: LCS 380-195112/22-A**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	1.97	1.99		ug/L		101	70 - 130
2,4'-DDD	1.97	1.90		ug/L		97	70 - 130
2,4'-DDE	1.97	2.10		ug/L		107	70 - 130
2,4'-DDT	1.97	1.95		ug/L		99	70 - 130
2,4-Dinitrotoluene	1.97	2.16		ug/L		110	70 - 130
2,6-Dinitrotoluene	1.97	2.05		ug/L		104	70 - 130
2-Methylnaphthalene	1.97	2.00		ug/L		101	70 - 130
4,4'-DDD	1.97	1.97		ug/L		100	70 - 130
4,4'-DDE	1.97	2.08		ug/L		106	70 - 130
4,4'-DDT	1.97	1.97		ug/L		100	70 - 130
Acenaphthene	1.97	1.99		ug/L		101	70 - 130
Acenaphthylene	1.97	2.18		ug/L		111	70 - 130
Acetochlor	1.97	2.10		ug/L		107	70 - 130
Alachlor	1.97	2.18		ug/L		111	70 - 130
alpha-BHC	1.97	2.20		ug/L		112	70 - 130
alpha-Chlordane	1.97	1.84		ug/L		93	70 - 130
Anthracene	1.97	2.21		ug/L		112	70 - 130
Atrazine	1.97	2.05		ug/L		104	70 - 130
Benz(a)anthracene	1.97	1.93		ug/L		98	70 - 130
Benzo[a]pyrene	1.97	2.04		ug/L		104	70 - 130
Benzo[b]fluoranthene	1.97	1.99		ug/L		101	70 - 130
Benzo[g,h,i]perylene	1.97	2.06		ug/L		104	70 - 130
Benzo[k]fluoranthene	1.97	1.80		ug/L		91	70 - 130
beta-BHC	1.97	2.18		ug/L		111	70 - 130
Bis(2-ethylhexyl) phthalate	1.97	2.07		ug/L		105	70 - 130
Bromacil	1.97	1.96		ug/L		100	70 - 130
Butachlor	1.97	2.30		ug/L		117	70 - 130
Butylbenzylphthalate	1.97	2.29		ug/L		116	70 - 130
Chlorobenzilate	1.97	2.04		ug/L		104	70 - 130
Chloroneb	1.97	2.13		ug/L		108	70 - 130
Chlorothalonil (Draconil, Bravo)	1.97	2.14		ug/L		109	70 - 130
Chlorpyrifos	1.97	1.92		ug/L		97	70 - 130
Chrysene	1.97	1.66		ug/L		84	70 - 130
delta-BHC	1.97	2.22		ug/L		113	70 - 130
Di(2-ethylhexyl)adipate	1.97	2.33		ug/L		118	70 - 130
Dibenz(a,h)anthracene	1.97	2.15		ug/L		109	70 - 130
Diclorvos (DDVP)	1.97	2.24		ug/L		114	70 - 130
Dieldrin	1.97	2.04		ug/L		104	70 - 130
Diethylphthalate	1.97	2.26		ug/L		115	70 - 130
Dimethylphthalate	1.97	2.24		ug/L		114	70 - 130
Di-n-butyl phthalate	3.94	4.14		ug/L		105	70 - 130
Di-n-octyl phthalate	1.97	2.00		ug/L		101	70 - 130
Endosulfan I (Alpha)	1.97	1.91		ug/L		97	70 - 130
Endosulfan II (Beta)	1.97	2.15		ug/L		109	70 - 130
Endosulfan sulfate	1.97	2.11		ug/L		107	70 - 130
Endrin	1.97	2.14		ug/L		108	70 - 130
Endrin aldehyde	1.97	1.93		ug/L		98	60 - 130
EPTC	1.97	2.33		ug/L		118	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: LCS 380-195112/22-A**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Fluoranthene	1.97	2.15		ug/L		109	70 - 130
Fluorene	1.97	2.15		ug/L		109	70 - 130
gamma-Chlordane	1.97	1.84		ug/L		94	70 - 130
Heptachlor	1.97	2.24		ug/L		114	70 - 130
Heptachlor epoxide (isomer B)	1.97	2.00		ug/L		102	70 - 130
Hexachlorobenzene	1.97	2.21		ug/L		112	70 - 130
Hexachlorocyclopentadiene	1.97	2.06		ug/L		105	70 - 130
Indeno[1,2,3-cd]pyrene	1.97	2.24		ug/L		114	70 - 130
Isophorone	1.97	1.95		ug/L		99	70 - 130
Lindane	1.97	2.15		ug/L		109	70 - 130
Malathion	1.97	2.19		ug/L		111	70 - 130
Methoxychlor	1.97	2.04		ug/L		103	70 - 130
Metolachlor	1.97	2.18		ug/L		111	70 - 130
Molinate	1.97	2.17		ug/L		110	70 - 130
Naphthalene	1.97	1.96		ug/L		99	70 - 130
Parathion	1.97	2.21		ug/L		113	70 - 130
Pendimethalin (Penoxaline)	1.97	2.04		ug/L		103	70 - 130
Phenanthrene	1.97	2.04		ug/L		104	70 - 130
Propachlor	1.97	2.14		ug/L		109	70 - 130
Pyrene	1.97	1.95		ug/L		99	70 - 130
Simazine	1.97	1.95		ug/L		99	70 - 130
Terbacil	1.97	2.02		ug/L		103	70 - 130
Terbutylazine	1.97	2.20		ug/L		112	70 - 130
Thiobencarb	1.97	2.08		ug/L		106	70 - 130
trans-Nonachlor	1.97	1.76		ug/L		89	70 - 130
Trifluralin	1.97	2.03		ug/L		103	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2-Nitro-m-xylene	95		70 - 130
Perylene-d12	101		70 - 130
Triphenylphosphate	106		70 - 130

**Lab Sample ID: MRL 380-195112/21-A**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	0.0985	0.116		ug/L		118	50 - 150
2,4'-DDD	0.0985	0.0850	J	ug/L		86	50 - 150
2,4'-DDE	0.0985	0.0894	J	ug/L		91	50 - 150
2,4'-DDT	0.0985	0.107		ug/L		109	50 - 150
2,4-Dinitrotoluene	0.0985	0.111		ug/L		112	50 - 150
2,6-Dinitrotoluene	0.0985	0.135		ug/L		137	50 - 150
2-Methylnaphthalene	0.0985	0.112		ug/L		113	50 - 150
4,4'-DDD	0.0985	0.114		ug/L		116	50 - 150
4,4'-DDE	0.0985	0.110		ug/L		112	50 - 150
4,4'-DDT	0.0985	0.115		ug/L		117	50 - 150
Acenaphthene	0.0985	0.0912	J	ug/L		93	50 - 150

# QC Sample Results

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-189450-1  
 SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: MRL 380-195112/21-A**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Acenaphthylene	0.0985	0.0848	J	ug/L		86	50 - 150
Acetochlor	0.0985	0.122		ug/L		124	50 - 150
Alachlor	0.0493	0.0545		ug/L		111	50 - 150
alpha-BHC	0.0985	0.0939	J	ug/L		95	50 - 150
alpha-Chlordane	0.0246	0.0301	J	ug/L		122	50 - 150
Anthracene	0.0197	0.0216		ug/L		109	50 - 150
Atrazine	0.0493	0.0657		ug/L		133	50 - 150
Benz(a)anthracene	0.0493	0.0564		ug/L		114	50 - 150
Benzo[a]pyrene	0.0197	0.0234		ug/L		119	50 - 150
Benzo[b]fluoranthene	0.0197	0.0199	J	ug/L		101	50 - 150
Benzo[g,h,i]perylene	0.0493	0.0488	J	ug/L		99	50 - 150
Benzo[k]fluoranthene	0.0197	0.0221		ug/L		112	50 - 150
beta-BHC	0.0985	0.111		ug/L		112	50 - 150
Bis(2-ethylhexyl) phthalate	0.591	0.646		ug/L		109	50 - 150
Bromacil	0.0985	0.118		ug/L		120	50 - 150
Butachlor	0.0493	0.0582		ug/L		118	50 - 150
Butylbenzylphthalate	0.493	0.560		ug/L		114	50 - 150
Chlorobenzilate	0.0985	0.117		ug/L		119	50 - 150
Chloroneb	0.0985	0.104		ug/L		106	50 - 150
Chlorothalonil (Draconil, Bravo)	0.0985	0.134		ug/L		136	50 - 150
Chlorpyrifos	0.0493	0.0663		ug/L		135	50 - 150
Chrysene	0.0197	0.0204		ug/L		104	50 - 150
delta-BHC	0.0985	0.0969	J	ug/L		98	50 - 150
Di(2-ethylhexyl)adipate	0.591	0.785		ug/L		133	50 - 150
Dibenz(a,h)anthracene	0.0493	0.0464	J	ug/L		94	50 - 150
Diclorvos (DDVP)	0.0493	0.0558		ug/L		113	50 - 150
Dieldrin	0.00985	0.00917	J	ug/L		93	50 - 150
Diethylphthalate	0.493	0.542		ug/L		110	50 - 150
Dimethylphthalate	0.493	0.502		ug/L		102	50 - 150
Di-n-butyl phthalate	0.493	0.513	J	ug/L		104	49 - 243
Di-n-octyl phthalate	0.0985	0.107		ug/L		108	50 - 150
Endosulfan I (Alpha)	0.0985	0.0908	J	ug/L		92	50 - 150
Endosulfan II (Beta)	0.0985	0.0943	J	ug/L		96	50 - 150
Endosulfan sulfate	0.0985	0.109		ug/L		111	50 - 150
Endrin	0.00985	0.00937	J	ug/L		95	50 - 150
Endrin aldehyde	0.0985	0.130		ug/L		132	50 - 150
EPTC	0.0985	0.108		ug/L		110	50 - 150
Fluoranthene	0.0985	0.102		ug/L		104	50 - 150
Fluorene	0.0493	0.0510		ug/L		104	50 - 150
gamma-Chlordane	0.0246	0.0287	J	ug/L		117	50 - 150
Heptachlor	0.00985	0.0128		ug/L		129	50 - 150
Heptachlor epoxide (isomer B)	0.00985	0.0154	^3+	ug/L		156	50 - 150
Hexachlorobenzene	0.0493	0.0448	J	ug/L		91	50 - 150
Hexachlorocyclopentadiene	0.0493	0.0473	J	ug/L		96	50 - 150
Indeno[1,2,3-cd]pyrene	0.0493	0.0520		ug/L		105	50 - 150
Isophorone	0.0985	0.109		ug/L		110	50 - 150
Lindane	0.00985	0.00983	J	ug/L		100	50 - 150
Malathion	0.0985	0.109		ug/L		111	50 - 150
Methoxychlor	0.0493	0.0579		ug/L		118	50 - 150

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: MRL 380-195112/21-A**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Metolachlor	0.0493	0.0546		ug/L		111	50 - 150
Molinate	0.0985	0.128		ug/L		130	50 - 150
Naphthalene	0.0985	0.112		ug/L		113	50 - 150
Parathion	0.0985	0.0885	J	ug/L		90	50 - 150
Pendimethalin (Penoxaline)	0.0985	0.0914	J	ug/L		93	50 - 150
Phenanthrene	0.0394	0.0469		ug/L		119	50 - 150
Propachlor	0.0493	0.0575		ug/L		117	50 - 150
Pyrene	0.0493	0.0565		ug/L		115	50 - 150
Simazine	0.0493	0.0549		ug/L		111	50 - 150
Terbacil	0.0985	0.101		ug/L		103	50 - 150
Terbutylazine	0.0985	0.108		ug/L		109	50 - 150
Thiobencarb	0.0985	0.113		ug/L		114	50 - 150
trans-Nonachlor	0.0246	<0.026		ug/L		103	50 - 150
Trifluralin	0.0985	0.101		ug/L		103	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
2-Nitro-m-xylene	95		70 - 130
Perylene-d12	88		70 - 130
Triphenylphosphate	104		70 - 130

**Lab Sample ID: 380-189454-I-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	<0.097		1.94	1.99		ug/L		102	70 - 130
2,4'-DDD	<0.097		1.94	1.89		ug/L		98	70 - 130
2,4'-DDE	<0.097		1.94	1.99		ug/L		103	70 - 130
2,4'-DDT	<0.097		1.94	1.78		ug/L		92	70 - 130
2,4-Dinitrotoluene	<0.097		1.94	2.22		ug/L		115	70 - 130
2,6-Dinitrotoluene	<0.097		1.94	2.05		ug/L		106	70 - 130
2-Methylnaphthalene	<0.097		1.94	1.97		ug/L		101	70 - 130
4,4'-DDD	<0.097		1.94	1.93		ug/L		100	70 - 130
4,4'-DDE	<0.097		1.94	1.90		ug/L		98	70 - 130
4,4'-DDT	<0.097		1.94	1.78		ug/L		92	70 - 130
Acenaphthene	<0.097		1.94	1.98		ug/L		102	70 - 130
Acenaphthylene	<0.097		1.94	2.14		ug/L		111	70 - 130
Acetochlor	<0.097		1.94	2.14		ug/L		111	70 - 130
Alachlor	<0.049		1.94	2.22		ug/L		115	70 - 130
alpha-BHC	<0.097		1.94	2.07		ug/L		107	70 - 130
alpha-Chlordane	<0.049		1.94	1.76		ug/L		91	70 - 130
Anthracene	<0.019		1.94	1.95		ug/L		101	70 - 130
Atrazine	<0.049		1.94	1.97		ug/L		102	70 - 130
Benz(a)anthracene	<0.049		1.94	1.86		ug/L		96	70 - 130
Benzo[a]pyrene	<0.019		1.94	2.01		ug/L		104	70 - 130
Benzo[b]fluoranthene	<0.019		1.94	2.03		ug/L		105	70 - 130
Benzo[g,h,i]perylene	<0.049		1.94	2.11		ug/L		109	70 - 130
Benzo[k]fluoranthene	<0.019		1.94	1.72		ug/L		89	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: 380-189454-I-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
beta-BHC	<0.097		1.94	2.10		ug/L		109	70 - 130
Bis(2-ethylhexyl) phthalate	<0.58		1.94	1.95		ug/L		101	70 - 130
Bromacil	<0.097		1.94	1.96		ug/L		101	70 - 130
Butachlor	<0.049		1.94	2.29		ug/L		118	70 - 130
Butylbenzylphthalate	<0.49		1.94	2.32		ug/L		120	70 - 130
Chlorobenzilate	<0.097		1.94	2.10		ug/L		109	70 - 130
Chloroneb	<0.097		1.94	2.07		ug/L		107	70 - 130
Chlorothalonil (Draconil, Bravo)	<0.097		1.94	2.21		ug/L		114	70 - 130
Chlorpyrifos	<0.049		1.94	1.88		ug/L		97	70 - 130
Chrysene	<0.019		1.94	1.66		ug/L		86	70 - 130
delta-BHC	<0.097		1.94	2.22		ug/L		115	70 - 130
Di(2-ethylhexyl)adipate	<0.58		1.94	2.17		ug/L		112	70 - 130
Dibenz(a,h)anthracene	<0.049		1.94	2.14		ug/L		111	70 - 130
Diclorvos (DDVP)	<0.049		1.94	2.21		ug/L		114	70 - 130
Dieldrin	<0.0097		1.94	2.07		ug/L		107	70 - 130
Diethylphthalate	<0.49		1.94	2.18		ug/L		113	70 - 130
Dimethylphthalate	<0.49		1.94	2.22		ug/L		115	70 - 130
Di-n-butyl phthalate	<0.97		3.87	4.17		ug/L		108	70 - 130
Di-n-octyl phthalate	<0.097		1.94	1.87		ug/L		97	70 - 130
Endosulfan I (Alpha)	<0.097		1.94	1.94		ug/L		100	70 - 130
Endosulfan II (Beta)	<0.097		1.94	2.11		ug/L		109	70 - 130
Endosulfan sulfate	<0.097		1.94	2.16		ug/L		112	70 - 130
Endrin	<0.0097		1.94	2.18		ug/L		112	70 - 130
Endrin aldehyde	<0.097		1.94	1.56		ug/L		81	60 - 130
EPTC	<0.097		1.94	2.27		ug/L		117	70 - 130
Fluoranthene	<0.097		1.94	2.12		ug/L		110	70 - 130
Fluorene	<0.049		1.94	2.14		ug/L		110	70 - 130
gamma-Chlordane	<0.049		1.94	1.80		ug/L		93	70 - 130
Heptachlor	<0.0097		1.94	2.21		ug/L		114	70 - 130
Heptachlor epoxide (isomer B)	<0.0097	^3+	1.94	2.00		ug/L		103	70 - 130
Hexachlorobenzene	<0.049		1.94	2.15		ug/L		111	70 - 130
Hexachlorocyclopentadiene	<0.049		1.94	1.86		ug/L		96	70 - 130
Indeno[1,2,3-cd]pyrene	<0.049		1.94	2.27		ug/L		117	70 - 130
Isophorone	<0.097		1.94	1.93		ug/L		100	70 - 130
Lindane	<0.0097		1.94	2.07		ug/L		107	70 - 130
Malathion	<0.097		1.94	2.15		ug/L		111	70 - 130
Methoxychlor	<0.049		1.94	2.00		ug/L		103	70 - 130
Metolachlor	<0.049		1.94	2.17		ug/L		112	70 - 130
Molinate	<0.097		1.94	2.13		ug/L		110	70 - 130
Naphthalene	<0.097		1.94	1.89		ug/L		98	70 - 130
Parathion	<0.097		1.94	2.29		ug/L		118	70 - 130
Pendimethalin (Penoxaline)	<0.097		1.94	2.17		ug/L		112	70 - 130
Phenanthrene	<0.039		1.94	2.03		ug/L		105	70 - 130
Propachlor	<0.049		1.94	2.10		ug/L		109	70 - 130
Pyrene	<0.049		1.94	1.97		ug/L		101	70 - 130
Simazine	<0.049		1.94	1.96		ug/L		101	70 - 130
Terbacil	<0.097		1.94	2.16		ug/L		112	70 - 130
Terbutylazine	<0.097		1.94	2.17		ug/L		112	70 - 130
Thiobencarb	<0.097		1.94	2.07		ug/L		107	70 - 130

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: 380-189454-I-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
trans-Nonachlor	<0.049		1.94	1.72		ug/L		89	70 - 130
Trifluralin	<0.097		1.94	2.09		ug/L		108	70 - 130
<b>MS MS</b>									
Surrogate	%Recovery	Qualifier	Limits						
2-Nitro-m-xylene	96		70 - 130						
Perylene-d12	104		70 - 130						
Triphenylphosphate	107		70 - 130						

**Lab Sample ID: 380-189454-J-1-A MSD**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec Limits	RPD	Limit
	Result	Qualifier	Added	Result	Qualifier						
1-Methylnaphthalene	<0.097		1.92	2.02		ug/L		104	70 - 130	1	20
2,4'-DDD	<0.097		1.92	1.91		ug/L		99	70 - 130	1	20
2,4'-DDE	<0.097		1.92	2.03		ug/L		106	70 - 130	2	20
2,4'-DDT	<0.097		1.92	1.81		ug/L		94	70 - 130	2	20
2,4-Dinitrotoluene	<0.097		1.92	2.31		ug/L		120	70 - 130	4	20
2,6-Dinitrotoluene	<0.097		1.92	2.17		ug/L		113	70 - 130	6	20
2-Methylnaphthalene	<0.097		1.92	2.00		ug/L		104	70 - 130	1	20
4,4'-DDD	<0.097		1.92	1.96		ug/L		102	70 - 130	2	20
4,4'-DDE	<0.097		1.92	1.91		ug/L		99	70 - 130	0	20
4,4'-DDT	<0.097		1.92	1.89		ug/L		98	70 - 130	6	20
Acenaphthene	<0.097		1.92	1.96		ug/L		102	70 - 130	1	20
Acenaphthylene	<0.097		1.92	2.20		ug/L		115	70 - 130	3	20
Acetochlor	<0.097		1.92	2.14		ug/L		111	70 - 130	0	20
Alachlor	<0.049		1.92	2.22		ug/L		115	70 - 130	0	20
alpha-BHC	<0.097		1.92	2.15		ug/L		112	70 - 130	4	20
alpha-Chlordane	<0.049		1.92	1.82		ug/L		95	70 - 130	3	20
Anthracene	<0.019		1.92	1.96		ug/L		102	70 - 130	1	20
Atrazine	<0.049		1.92	2.08		ug/L		108	70 - 130	5	20
Benz(a)anthracene	<0.049		1.92	1.91		ug/L		99	70 - 130	2	20
Benzo[a]pyrene	<0.019		1.92	1.98		ug/L		103	70 - 130	1	20
Benzo[b]fluoranthene	<0.019		1.92	1.97		ug/L		103	70 - 130	3	20
Benzo[g,h,i]perylene	<0.049		1.92	2.04		ug/L		106	70 - 130	3	20
Benzo[k]fluoranthene	<0.019		1.92	1.71		ug/L		89	70 - 130	1	20
beta-BHC	<0.097		1.92	2.16		ug/L		112	70 - 130	2	20
Bis(2-ethylhexyl) phthalate	<0.58		1.92	1.93		ug/L		100	70 - 130	1	20
Bromacil	<0.097		1.92	1.94		ug/L		101	70 - 130	1	20
Butachlor	<0.049		1.92	2.26		ug/L		118	70 - 130	1	20
Butylbenzylphthalate	<0.49		1.92	2.29		ug/L		119	70 - 130	1	20
Chlorobenzilate	<0.097		1.92	2.11		ug/L		110	70 - 130	0	20
Chloroneb	<0.097		1.92	2.13		ug/L		111	70 - 130	3	20
Chlorothalonil (Draconil, Bravo)	<0.097		1.92	2.27		ug/L		118	70 - 130	3	20
Chlorpyrifos	<0.049		1.92	1.95		ug/L		102	70 - 130	4	20
Chrysene	<0.019		1.92	1.63		ug/L		85	70 - 130	2	20
delta-BHC	<0.097		1.92	2.22		ug/L		116	70 - 130	0	20
Di(2-ethylhexyl)adipate	<0.58		1.92	2.19		ug/L		114	70 - 130	1	20

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: 380-189454-J-1-A MSD**  
**Matrix: Water**  
**Analysis Batch: 195340**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 195112**

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec		RPD	Limit
	Result	Qualifier	Added	Result	Qualifier				Limits	RPD		
Dibenz(a,h)anthracene	<0.049		1.92	2.12		ug/L		110	70 - 130	1	20	
Diclorvos (DDVP)	<0.049		1.92	2.32		ug/L		121	70 - 130	5	20	
Dieldrin	<0.0097		1.92	2.10		ug/L		109	70 - 130	1	20	
Diethylphthalate	<0.49		1.92	2.30		ug/L		120	70 - 130	5	20	
Dimethylphthalate	<0.49		1.92	2.29		ug/L		119	70 - 130	3	20	
Di-n-butyl phthalate	<0.97		3.84	4.18		ug/L		109	70 - 130	0	20	
Di-n-octyl phthalate	<0.097		1.92	1.79		ug/L		93	70 - 130	4	20	
Endosulfan I (Alpha)	<0.097		1.92	1.91		ug/L		100	70 - 130	2	20	
Endosulfan II (Beta)	<0.097		1.92	2.10		ug/L		109	70 - 130	1	20	
Endosulfan sulfate	<0.097		1.92	2.18		ug/L		114	70 - 130	1	20	
Endrin	<0.0097		1.92	2.21		ug/L		115	70 - 130	2	20	
Endrin aldehyde	<0.097		1.92	1.58		ug/L		82	60 - 130	1	20	
EPTC	<0.097		1.92	2.32		ug/L		121	70 - 130	2	20	
Fluoranthene	<0.097		1.92	2.12		ug/L		110	70 - 130	0	20	
Fluorene	<0.049		1.92	2.17		ug/L		113	70 - 130	1	20	
gamma-Chlordane	<0.049		1.92	1.88		ug/L		98	70 - 130	4	20	
Heptachlor	<0.0097		1.92	2.25		ug/L		117	70 - 130	2	20	
Heptachlor epoxide (isomer B)	<0.0097	^3+	1.92	1.98		ug/L		103	70 - 130	1	20	
Hexachlorobenzene	<0.049		1.92	2.17		ug/L		113	70 - 130	1	20	
Hexachlorocyclopentadiene	<0.049		1.92	2.01		ug/L		105	70 - 130	8	20	
Indeno[1,2,3-cd]pyrene	<0.049		1.92	2.24		ug/L		117	70 - 130	2	20	
Isophorone	<0.097		1.92	1.96		ug/L		102	70 - 130	1	20	
Lindane	<0.0097		1.92	2.14		ug/L		111	70 - 130	3	20	
Malathion	<0.097		1.92	2.18		ug/L		114	70 - 130	1	20	
Methoxychlor	<0.049		1.92	2.04		ug/L		106	70 - 130	2	20	
Metolachlor	<0.049		1.92	2.14		ug/L		112	70 - 130	2	20	
Molinate	<0.097		1.92	2.19		ug/L		114	70 - 130	3	20	
Naphthalene	<0.097		1.92	1.93		ug/L		101	70 - 130	2	20	
Parathion	<0.097		1.92	2.33		ug/L		121	70 - 130	2	20	
Pendimethalin (Penoxaline)	<0.097		1.92	2.24		ug/L		117	70 - 130	3	20	
Phenanthrene	<0.039		1.92	2.02		ug/L		105	70 - 130	1	20	
Propachlor	<0.049		1.92	2.15		ug/L		112	70 - 130	2	20	
Pyrene	<0.049		1.92	1.96		ug/L		102	70 - 130	1	20	
Simazine	<0.049		1.92	1.99		ug/L		104	70 - 130	2	20	
Terbacil	<0.097		1.92	2.17		ug/L		113	70 - 130	0	20	
Terbutylazine	<0.097		1.92	2.24		ug/L		117	70 - 130	3	20	
Thiobencarb	<0.097		1.92	2.10		ug/L		109	70 - 130	1	20	
trans-Nonachlor	<0.049		1.92	1.71		ug/L		89	70 - 130	1	20	
Trifluralin	<0.097		1.92	2.16		ug/L		113	70 - 130	3	20	

Surrogate	MSD		Limits
	%Recovery	Qualifier	
2-Nitro-m-xylene	97		70 - 130
Perylene-d12	105		70 - 130
Triphenylphosphate	108		70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

**Lab Sample ID: MB 570-675514/1-A**  
**Matrix: Water**  
**Analysis Batch: 679405**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 675514**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
2-Methylnaphthalene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Acenaphthene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Acenaphthylene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Anthracene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Benzo[a]anthracene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Benzo[a]pyrene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Benzo[b]fluoranthene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Benzo[g,h,i]perylene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Benzo[k]fluoranthene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Chrysene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Dibenz(a,h)anthracene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Fluoranthene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Fluorene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Naphthalene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Phenanthrene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1
Pyrene	<0.20		0.20	ug/L		12/26/25 13:32	01/06/26 20:21	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	89		28 - 127	12/26/25 13:32	01/06/26 20:21	1
2-Fluorobiphenyl (Surr)	83		31 - 120	12/26/25 13:32	01/06/26 20:21	1
2-Fluorophenol (Surr)	61		17 - 120	12/26/25 13:32	01/06/26 20:21	1
Nitrobenzene-d5 (Surr)	89		27 - 120	12/26/25 13:32	01/06/26 20:21	1
Phenol-d6 (Surr)	38		10 - 120	12/26/25 13:32	01/06/26 20:21	1
p-Terphenyl-d14 (Surr)	93		45 - 120	12/26/25 13:32	01/06/26 20:21	1

**Lab Sample ID: LCS 570-675514/2-A**  
**Matrix: Water**  
**Analysis Batch: 679405**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 675514**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	20.0	15.9		ug/L		79	47 - 120
2-Methylnaphthalene	20.0	15.7		ug/L		78	43 - 120
Acenaphthene	20.0	19.0		ug/L		95	60 - 132
Acenaphthylene	20.0	19.1		ug/L		96	54 - 126
Anthracene	20.0	19.0		ug/L		95	43 - 120
Benzo[a]anthracene	20.0	21.4		ug/L		107	42 - 133
Benzo[a]pyrene	20.0	19.7		ug/L		99	32 - 148
Benzo[b]fluoranthene	20.0	21.4		ug/L		107	42 - 140
Benzo[g,h,i]perylene	20.0	20.3		ug/L		101	1 - 195
Benzo[k]fluoranthene	20.0	20.1		ug/L		100	25 - 146
Chrysene	20.0	19.9		ug/L		100	44 - 140
Dibenz(a,h)anthracene	20.0	22.1		ug/L		111	1 - 200
Fluoranthene	20.0	20.3		ug/L		102	43 - 121
Fluorene	20.0	19.6		ug/L		98	70 - 120
Indeno[1,2,3-cd]pyrene	20.0	23.0		ug/L		115	1 - 151
Naphthalene	20.0	14.6		ug/L		73	36 - 120

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

**Lab Sample ID: LCS 570-675514/2-A**  
**Matrix: Water**  
**Analysis Batch: 679405**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 675514**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Phenanthrene	20.0	19.4		ug/L		97	65 - 120
Pyrene	20.0	20.9		ug/L		105	70 - 120

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2,4,6-Tribromophenol (Surr)	46		28 - 127
2-Fluorobiphenyl (Surr)	43		31 - 120
2-Fluorophenol (Surr)	32		17 - 120
Nitrobenzene-d5 (Surr)	38		27 - 120
Phenol-d6 (Surr)	21		10 - 120
p-Terphenyl-d14 (Surr)	50		45 - 120

**Lab Sample ID: LCSD 570-675514/3-A**  
**Matrix: Water**  
**Analysis Batch: 679405**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 675514**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	Limit
1-Methylnaphthalene	20.0	15.9		ug/L		79	47 - 120	0	20
2-Methylnaphthalene	20.0	15.5		ug/L		78	43 - 120	1	20
Acenaphthene	20.0	18.6		ug/L		93	60 - 132	2	29
Acenaphthylene	20.0	18.7		ug/L		94	54 - 126	2	45
Anthracene	20.0	19.3		ug/L		96	43 - 120	1	40
Benzo[a]anthracene	20.0	20.9		ug/L		104	42 - 133	2	32
Benzo[a]pyrene	20.0	19.9		ug/L		100	32 - 148	1	43
Benzo[b]fluoranthene	20.0	20.1		ug/L		101	42 - 140	6	43
Benzo[g,h,i]perylene	20.0	19.8		ug/L		99	1 - 195	2	61
Benzo[k]fluoranthene	20.0	19.1		ug/L		95	25 - 146	5	38
Chrysene	20.0	19.4		ug/L		97	44 - 140	3	53
Dibenz(a,h)anthracene	20.0	21.4		ug/L		107	1 - 200	4	75
Fluoranthene	20.0	19.7		ug/L		99	43 - 121	3	40
Fluorene	20.0	18.9		ug/L		95	70 - 120	3	23
Indeno[1,2,3-cd]pyrene	20.0	21.9		ug/L		110	1 - 151	5	60
Naphthalene	20.0	14.4		ug/L		72	36 - 120	1	39
Phenanthrene	20.0	18.7		ug/L		94	65 - 120	4	24
Pyrene	20.0	20.7		ug/L		103	70 - 120	1	30

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
2,4,6-Tribromophenol (Surr)	43		28 - 127
2-Fluorobiphenyl (Surr)	43		31 - 120
2-Fluorophenol (Surr)	32		17 - 120
Nitrobenzene-d5 (Surr)	37		27 - 120
Phenol-d6 (Surr)	21		10 - 120
p-Terphenyl-d14 (Surr)	49		45 - 120

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 8015B GRO LL - Gasoline Range Organics - (GC)

**Lab Sample ID: MB 570-675935/6**  
**Matrix: Water**  
**Analysis Batch: 675935**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			12/28/25 12:55	1
Surrogate	MB %Recovery	MB Qualifier	Limits			Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	101		38 - 134				12/28/25 12:55	1

**Lab Sample ID: LCS 570-675935/4**  
**Matrix: Water**  
**Analysis Batch: 675935**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	400	389		ug/L		97	78 - 120
Surrogate	LCS %Recovery	LCS Qualifier	Limits				
4-Bromofluorobenzene (Surr)	100		38 - 134				

**Lab Sample ID: LCSD 570-675935/5**  
**Matrix: Water**  
**Analysis Batch: 675935**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	Limit
Gasoline Range Organics (C4-C13)	400	396		ug/L		99	78 - 120	2	10
Surrogate	LCSD %Recovery	LCSD Qualifier	Limits						
4-Bromofluorobenzene (Surr)	105		38 - 134						

**Lab Sample ID: MRL 570-675935/3**  
**Matrix: Water**  
**Analysis Batch: 675935**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	10.0	11.9		ug/L		119	50 - 150
Surrogate	MRL %Recovery	MRL Qualifier	Limits				
4-Bromofluorobenzene (Surr)	93		38 - 134				

**Lab Sample ID: 380-189446-E-1 MS**  
**Matrix: Water**  
**Analysis Batch: 675935**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	<10		400	412		ug/L		103	68 - 122
Surrogate	MS %Recovery	MS Qualifier	Limits						
4-Bromofluorobenzene (Surr)	103		38 - 134						

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 8015B GRO LL - Gasoline Range Organics - (GC)

**Lab Sample ID: 380-189446-E-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 675935**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	383		ug/L		96	68 - 122	7	18
<b>Surrogate</b>		<b>MSD %Recovery</b>		<b>MSD Qualifier</b>							<b>Limits</b>
4-Bromofluorobenzene (Surr)		101									38 - 134

**Lab Sample ID: MB 570-678421/13**  
**Matrix: Water**  
**Analysis Batch: 678421**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			01/04/26 18:26	1
<b>Surrogate</b>		<b>MB %Recovery</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
4-Bromofluorobenzene (Surr)		98					01/04/26 18:26	1

**Lab Sample ID: LCS 570-678421/1011**  
**Matrix: Water**  
**Analysis Batch: 678421**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	400	444		ug/L		111	78 - 120
<b>Surrogate</b>		<b>LCS %Recovery</b>					<b>Limits</b>
4-Bromofluorobenzene (Surr)		91					38 - 134

**Lab Sample ID: LCSD 570-678421/12**  
**Matrix: Water**  
**Analysis Batch: 678421**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	400	426		ug/L		107	78 - 120	4	10
<b>Surrogate</b>		<b>LCSD %Recovery</b>					<b>Limits</b>		
4-Bromofluorobenzene (Surr)		94					38 - 134		

**Lab Sample ID: MRL 570-678421/14**  
**Matrix: Water**  
**Analysis Batch: 678421**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	10.0	9.44	J	ug/L		94	50 - 150
<b>Surrogate</b>		<b>MRL %Recovery</b>					<b>Limits</b>
4-Bromofluorobenzene (Surr)		94					38 - 134

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 8015B GRO LL - Gasoline Range Organics - (GC)

**Lab Sample ID: 380-190087-C-1 MS**  
**Matrix: Water**  
**Analysis Batch: 678421**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits	
Gasoline Range Organics (C4-C13)	<10	F1	400	490		ug/L		122	68 - 122	
<b>Surrogate</b>	<b>%Recovery</b>	<b>MS Qualifier</b>	<b>MS Limits</b>							
4-Bromofluorobenzene (Surr)	102		38 - 134							

**Lab Sample ID: 380-190087-C-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 678421**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10	F1	400	498	F1	ug/L		125	68 - 122	2	18
<b>Surrogate</b>	<b>%Recovery</b>	<b>MSD Qualifier</b>	<b>MSD Limits</b>								
4-Bromofluorobenzene (Surr)	107		38 - 134								

## Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

**Lab Sample ID: MB 570-675474/1-A**  
**Matrix: Water**  
**Analysis Batch: 679396**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 675474**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac	
Diesel Range Organics (C10-C24)	<25		25	ug/L		12/26/25 12:28	01/07/26 06:32	1	
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		12/26/25 12:28	01/07/26 06:32	1	
C8-C18	<25		25	ug/L		12/26/25 12:28	01/07/26 06:32	1	
<b>Surrogate</b>	<b>%Recovery</b>	<b>MB Qualifier</b>	<b>MB Limits</b>	<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>			
n-Octacosane (Surr)	97		60 - 130	12/26/25 12:28	01/07/26 06:32	1			

**Lab Sample ID: LCS 570-675474/2-A**  
**Matrix: Water**  
**Analysis Batch: 679396**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 675474**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
C10-C28	1600	1380		ug/L		87	56 - 127
<b>Surrogate</b>	<b>%Recovery</b>	<b>LCS Qualifier</b>	<b>LCS Limits</b>				
n-Octacosane (Surr)	131	S1+	60 - 130				

**Lab Sample ID: LCSD 570-675474/3-A**  
**Matrix: Water**  
**Analysis Batch: 679396**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 675474**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
C10-C28	1600	1380		ug/L		86	56 - 127	0	23

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

**Lab Sample ID: LCSD 570-675474/3-A**  
**Matrix: Water**  
**Analysis Batch: 679396**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 675474**

	<i>LCSD</i>	<i>LCSD</i>	<i>Limits</i>
<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>
<i>n-Octacosane (Surr)</i>	112		60 - 130

**Lab Sample ID: MRL 570-675474/4-A**  
**Matrix: Water**  
**Analysis Batch: 679714**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 675474**

	<i>Spike</i>	<i>MRL</i>	<i>MRL</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>Limits</i>
<i>Analyte</i>	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>Limits</i>
C10-C28	0.0200	0.0231	J	mg/L		116	50 - 150

	<i>MRL</i>	<i>MRL</i>	<i>Limits</i>
<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>
<i>n-Octacosane (Surr)</i>	153		60 - 130

**Lab Sample ID: 380-189454-A-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 679714**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 675474**

	<i>Sample</i>	<i>Sample</i>	<i>Spike</i>	<i>MS</i>	<i>MS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>Limits</i>
<i>Analyte</i>	<i>Result</i>	<i>Qualifier</i>	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>Limits</i>
C10-C28	<26		1680	1570		ug/L		93	70 - 130

	<i>MS</i>	<i>MS</i>	<i>Limits</i>
<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>
<i>n-Octacosane (Surr)</i>	116		60 - 130

**Lab Sample ID: 380-189454-A-1-B MSD**  
**Matrix: Water**  
**Analysis Batch: 679714**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 675474**

	<i>Sample</i>	<i>Sample</i>	<i>Spike</i>	<i>MSD</i>	<i>MSD</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>Limits</i>	<i>RPD</i>	<i>RPD</i>
<i>Analyte</i>	<i>Result</i>	<i>Qualifier</i>	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>Limits</i>	<i>RPD</i>	<i>Limit</i>
C10-C28	<26		1650	1460		ug/L		88	70 - 130	8	20

	<i>MSD</i>	<i>MSD</i>	<i>Limits</i>
<i>Surrogate</i>	<i>%Recovery</i>	<i>Qualifier</i>	<i>Limits</i>
<i>n-Octacosane (Surr)</i>	144	S1+	60 - 130

# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## GC/MS Semi VOA

### Prep Batch: 195112

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189450-1	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	525.2	
380-189450-3	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	525.2	
MB 380-195112/20-A	Method Blank	Total/NA	Water	525.2	
LCS 380-195112/22-A	Lab Control Sample	Total/NA	Water	525.2	
MRL 380-195112/21-A	Lab Control Sample	Total/NA	Water	525.2	
380-189454-I-1-A MS	Matrix Spike	Total/NA	Water	525.2	
380-189454-J-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	525.2	

### Analysis Batch: 195340

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189450-1	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	525.2	195112
380-189450-3	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	525.2	195112
MB 380-195112/20-A	Method Blank	Total/NA	Water	525.2	195112
LCS 380-195112/22-A	Lab Control Sample	Total/NA	Water	525.2	195112
MRL 380-195112/21-A	Lab Control Sample	Total/NA	Water	525.2	195112
380-189454-I-1-A MS	Matrix Spike	Total/NA	Water	525.2	195112
380-189454-J-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	525.2	195112

### Prep Batch: 675514

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189450-3	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	625.1	
MB 570-675514/1-A	Method Blank	Total/NA	Water	625.1	
LCS 570-675514/2-A	Lab Control Sample	Total/NA	Water	625.1	
LCSD 570-675514/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	

### Analysis Batch: 679405

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 570-675514/1-A	Method Blank	Total/NA	Water	625.1 SIM	675514
LCS 570-675514/2-A	Lab Control Sample	Total/NA	Water	625.1 SIM	675514
LCSD 570-675514/3-A	Lab Control Sample Dup	Total/NA	Water	625.1 SIM	675514

### Analysis Batch: 679667

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189450-3	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	625.1 SIM	675514

### Analysis Batch: 681247

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189450-3	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	625.1	675514

## GC VOA

### Analysis Batch: 675935

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189450-1	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	8015B GRO LL	
380-189450-4	TB: AIEA GULCH WELLS PUMP 2 (331-202-TPC	Total/NA	Water	8015B GRO LL	
MB 570-675935/6	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-675935/4	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-675935/5	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-675935/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-189446-E-1 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-189446-E-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## GC VOA

### Analysis Batch: 678421

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189450-2	TB: AIEA GULCH WELLS PUMP 1 (331-201-TPC	Total/NA	Water	8015B GRO LL	
380-189450-3	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	8015B GRO LL	
MB 570-678421/13	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-678421/1011	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-678421/12	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-678421/14	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-190087-C-1 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-190087-C-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

## GC Semi VOA

### Prep Batch: 675474

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189450-1 - RA	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	3510C	
380-189450-3 - RA	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	3510C	
MB 570-675474/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-675474/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-675474/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
MRL 570-675474/4-A	Lab Control Sample	Total/NA	Water	3510C	
380-189454-A-1-A MS	Matrix Spike	Total/NA	Water	3510C	
380-189454-A-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	3510C	

### Analysis Batch: 679396

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 570-675474/1-A	Method Blank	Total/NA	Water	8015B	675474
LCS 570-675474/2-A	Lab Control Sample	Total/NA	Water	8015B	675474
LCSD 570-675474/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	675474

### Analysis Batch: 679714

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-189450-1 - RA	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Total/NA	Drinking Water	8015B	675474
380-189450-3 - RA	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Total/NA	Drinking Water	8015B	675474
MRL 570-675474/4-A	Lab Control Sample	Total/NA	Water	8015B	675474
380-189454-A-1-A MS	Matrix Spike	Total/NA	Water	8015B	675474
380-189454-A-1-B MSD	Matrix Spike Duplicate	Total/NA	Water	8015B	675474

# Lab Chronicle

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

**Client Sample ID: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-189450-1**

**Date Collected: 12/22/25 09:00**

**Matrix: Drinking Water**

**Date Received: 12/24/25 10:37**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			195112	IQ42	EA POM	12/30/25 15:37
Total/NA	Analysis	525.2		1	195340	Q8LA	EA POM	12/31/25 18:48
Total/NA	Analysis	8015B GRO LL		1	675935	AJG4	EET CAL 4	12/28/25 23:04
Total/NA	Prep	3510C	RA		675474	TVD6	EET CAL 4	12/27/25 09:07
Total/NA	Analysis	8015B	RA	1	679714	NR	EET CAL 4	01/07/26 18:34

**Client Sample ID: TB: AIEA GULCH WELLS PUMP 1  
(331-201-TP071)**

**Lab Sample ID: 380-189450-2**

**Date Collected: 12/22/25 09:00**

**Matrix: Water**

**Date Received: 12/24/25 10:37**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015B GRO LL		1	678421	YD9V	EET CAL 4	01/05/26 00:09

**Client Sample ID: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-189450-3**

**Date Collected: 12/22/25 09:00**

**Matrix: Drinking Water**

**Date Received: 12/24/25 10:37**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			195112	IQ42	EA POM	12/30/25 15:37
Total/NA	Analysis	525.2		1	195340	Q8LA	EA POM	12/31/25 19:08
Total/NA	Prep	625.1			675514	VAW2	EET CAL 4	12/27/25 08:18
Total/NA	Analysis	625.1		1	681247	PQS1	EET CAL 4	01/12/26 14:48
Total/NA	Prep	625.1			675514	VAW2	EET CAL 4	12/27/25 08:18
Total/NA	Analysis	625.1 SIM		1	679667	PQS1	EET CAL 4	01/07/26 14:19
Total/NA	Analysis	8015B GRO LL		1	678421	YD9V	EET CAL 4	01/04/26 20:28
Total/NA	Prep	3510C	RA		675474	TVD6	EET CAL 4	12/27/25 09:07
Total/NA	Analysis	8015B	RA	1	679714	NR	EET CAL 4	01/07/26 18:55

**Client Sample ID: TB: AIEA GULCH WELLS PUMP 2  
(331-202-TP072)**

**Lab Sample ID: 380-189450-4**

**Date Collected: 12/22/25 09:00**

**Matrix: Water**

**Date Received: 12/24/25 10:37**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015B GRO LL		1	675935	AJG4	EET CAL 4	12/28/25 20:52

**Laboratory References:**

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100  
EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

# Accreditation/Certification Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Laboratory: Eurofins Pomona

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26
<p>The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.</p>			
Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Drinking Water	1-Methylnaphthalene
525.2	525.2	Drinking Water	2,4'-DDD
525.2	525.2	Drinking Water	2,4'-DDE
525.2	525.2	Drinking Water	2,4'-DDT
525.2	525.2	Drinking Water	2,4-Dinitrotoluene
525.2	525.2	Drinking Water	2,6-Dinitrotoluene
525.2	525.2	Drinking Water	2-Methylnaphthalene
525.2	525.2	Drinking Water	4,4'-DDD
525.2	525.2	Drinking Water	4,4'-DDE
525.2	525.2	Drinking Water	4,4' DDT
525.2	525.2	Drinking Water	Acetochlor
525.2	525.2	Drinking Water	alpha-BHC
525.2	525.2	Drinking Water	alpha-Chlordane
525.2	525.2	Drinking Water	beta-BHC
525.2	525.2	Drinking Water	Chlorobenzilate
525.2	525.2	Drinking Water	Chloroneb
525.2	525.2	Drinking Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Drinking Water	Chlorpyrifos
525.2	525.2	Drinking Water	delta-BHC
525.2	525.2	Drinking Water	Diclorvos (DDVP)
525.2	525.2	Drinking Water	Endosulfan I (Alpha)
525.2	525.2	Drinking Water	Endosulfan II (Beta)
525.2	525.2	Drinking Water	Endosulfan sulfate
525.2	525.2	Drinking Water	Endrin aldehyde
525.2	525.2	Drinking Water	EPTC
525.2	525.2	Drinking Water	gamma-Chlordane
525.2	525.2	Drinking Water	Isophorone
525.2	525.2	Drinking Water	Malathion
525.2	525.2	Drinking Water	Parathion
525.2	525.2	Drinking Water	Pendimethalin (Penoxaline)
525.2	525.2	Drinking Water	Terbacil
525.2	525.2	Drinking Water	Terbutylazine
525.2	525.2	Drinking Water	Total Permethrin (mixed isomers)
525.2	525.2	Drinking Water	trans-Nonachlor

## Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	Dept. of Defense ELAP	7296.01	11-30-26
A2LA	ISO/IEC 17025	7296.01	11-30-26
Alaska (UST)	State	25-005	03-02-26
Arizona	State	AZ0830	11-17-26
California	Los Angeles County Sanitation Districts	9257304	07-31-26
California	SCAQMD LAP	17LA0919	11-30-26

# Accreditation/Certification Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

## Laboratory: Eurofins Calscience (Continued)

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
California	State	3082	07-31-26
Kansas	NELAP	E-10420	07-31-26
Nevada	State	CA00111	07-31-26
Oregon	NELAP	4175	02-02-26
USDA	US Federal Programs	525-23-159-97150	06-08-26
Utah	NELAP	CA00111	02-28-26
Washington	State	C916	10-11-26

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

# Method Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

Method	Method Description	Protocol	Laboratory
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA POM
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET CAL 4
625.1 SIM	Semivolatile Organic Compounds GC/MS (SIM)	EPA	EET CAL 4
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
525.2	Extraction of Semivolatile Compounds	EPA	EA POM
625.1	Liquid-Liquid Extraction	40CFR136A	EET CAL 4

#### Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

#### Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

# Sample Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-189450-1  
SDG: Weekly: Aiea Gulch Pump 1/Pump2

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-189450-1	AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Drinking Water	12/22/25 09:00	12/24/25 10:37	Hawaii
380-189450-2	TB: AIEA GULCH WELLS PUMP 1 (331-201-TP071)	Water	12/22/25 09:00	12/24/25 10:37	Hawaii
380-189450-3	AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Drinking Water	12/22/25 09:00	12/24/25 10:37	Hawaii
380-189450-4	TB: AIEA GULCH WELLS PUMP 2 (331-202-TP072)	Water	12/22/25 09:00	12/24/25 10:37	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

**Eurofins Eaton Analytical Pomona**

941 Corporate Center Drive  
 Pomona, CA 91768-2642  
 Phone (626) 386-1100

**Chain of Custody Record**



<b>Client Information</b>		Sampler:		Lab PM:		Carrier Tracking No(s):		COG No:	
Client Contact: Kirk Iwamoto		Phone: +1 808 748 5840		Arada, Rachelle		State of Origin:		380-28005-2757.1	
Company: City & County of Honolulu		PWSID:		E-Mail: Rachelle.Arada@et.eurofinsus.com		Analysis Requested		Page: Page 1 of 1	
Address: 630 South Beretania Street Chemistry Lab		Due Date Requested:		Field Filtered Sample (Yes or No)		Total Number of Containers		Job #:	
City: Honolulu		TAT Requested (days):		Perform MS/MSD (Yes or No)		R		Preservation Codes: R - NaThioSO4 RA - NaThio/HCl Q - Na2SO3 QA - Na2SO3/HCl Y - Trizma I - NH4 Acetate	
State, Zip: HI, 96843		Compliance Project: <input type="checkbox"/> Yes <input type="checkbox"/> No		625.1, 625.1, SIM		RA		Other:	
Phone: 808-748-5840 (Tel)		PO #: C20925101 exp 05312023		4015B_GRO_LL - (MOD) GRO		Q			
Email: kiwamoto@hbws.org		WO #:		4015B_DRO_LL_CS - HNL Ranges: C10-C24/C24-C36/C36-C18		QA			
Project Name: RED-HILL/HBWS Sites Event Desc: RUSH Weekly Red Hill		Project #: 38001111		925.2_PREC - (MOD) 925plus Plus TIOs		Y			
Site: Hawaii		SSOW#:		637.1_DW_PREC - 637.1 Full List		I			
				633 - All Analytes					
<b>Sample Identification</b>		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=waste/soil, BT=Tissue, A=Air)	
						Preservation Code:			
Aiea Gulch Pump 1		22-Dec-2025		9:00		G Water			
Aiea Gulch Pump 1 (Matrix Spike)		22-Dec-2025		9:00		G Water			
Aiea Gulch Pump 1 (Matrix Spike Duplicate)		22-Dec-2025		9:00		G Water			
TB: Aiea Gulch Pump 1								380-189450 COC	
Aiea Gulch Pump 2		22-Dec-2025		9:00		G Water		Lid broken for 625.1	
Aiea Gulch Pump 2 (Matrix Spike)		22-Dec-2025		9:00		G Water			
Aiea Gulch Pump 2 (Matrix Spike Duplicate)		22-Dec-2025		9:00		G Water			
TB: Aiea Gulch Pump 2		22-Dec-2025		9:00		G Water			
<b>Possible Hazard Identification</b>					<b>Sample Disposal ( A fee may be assessed if samples are retained longer than 1 month)</b>				
<input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological					<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months				
Deliverable Requested: I, II, III, IV, Other (specify)					Special Instructions/QC Requirements:				
Empty Kit Relinquished by:		Date:		Time:		Method of Shipment: 8893 STA 3071 100X			
Relinquished by:		Date/Time: 12/22/25 11:00		Company: HBWS		Received by: [Signature]		Date/Time: 12/25 1637	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Custody Seals Intact: <input type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks: 0.7/0.7 631A Blue Ice					

PAUL FROZOV



ORIGIN ID:HIKA (808) 748-5840  
BWS CHEMLAB  
HONOLULU BOARD OF WATER SUPPLY  
630 S. BERETANIA ST  
CHEMICAL LABORATORY  
HONOLULU HI 96843  
UNITED STATES US

SHIP DATE: 22DEC25  
ACTWGT: 58.00 LB  
CAD: 259050552/NET4535

BILL RECIPIENT

TO EUROFINS RECEIVING DEPARTMENT  
EUROFINS DRINKING WATER TESTING  
941 CORPORATE CENTER DR

POMONA CA 91768


(626) 386-1100

REF:

INV:  
PO:

DEPT:

5841507E59F2



FedEx  
Express



03402931451tr

6 of 7

TUE - 23 DEC 12:00P  
PRIORITY OVERNIGHT

MPS# 8873 5122 3271


Mstr# 8873 5122 3227

0201

WM ONTA

91768

CA-US ONT



After printing this label  
CONSIGNEE COPY PLEASE PLACE IN FRONT OF POUCH  
1 Fold the printed page along the horizontal line  
2 Place label in shipping pouch and affix it to your shipment.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16



## Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-189450-1  
SDG Number: Weekly: Aiea Gulch Pump 1/Pump2


**Login Number: 189450**

**List Number: 1**

**Creator: Sanchez, Joseph G**

**List Source: Eurofins Pomona**

Question	Answer	Comment
The coolers custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	



## Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-189450-1  
SDG Number: Weekly: Aiea Gulch Pump 1/Pump2

**Login Number: 189450**  
**List Number: 2**  
**Creator: Szyborski, Jessica**

**List Source: Eurofins Calscience**  
**List Creation: 12/26/25 01:19 PM**

Question	Answer	Comment
Radioactivity wasn't checked or is <math>\leq</math> background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	1.9/2.1
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <math><6\text{mm}</math> (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

